

27 November, 2024

Ingenia
 Attention: Harry Brazil
 Suite 1, 257 Gympie Road
 Kedron, QLD - 4031.

Dear Harry,

RE: MERRY BEACH CARAVAN PARK, MONTHLY REVIEW OF LABORATORY RESULTS – SEWAGE TREATMENT AND REUSE SYSTEM – OCTOBER 2024

Further to recommendations in Merry Beach Annual Monitoring Report find below the monthly review of monitoring data for September 30 to October 27, 2024.

1. Collection of water samples

Water samples for selected monitoring points were collected on the following dates:

- o October 24 – Eff1 and influent.
- o October 14 – SW1, SW2 and SW3.
- o October 24 - Drinking water samples from Creek Tanks, Main Tank and Pretty Beach Tank were sampled.

World Class Sustainable Engineering Solutions

Environmental

EIS & REF
 Streams & rivers
 Coastal
 Groundwater
 Catchments
 Bushfire
 Monitoring

Geotechnics

Foundations
 Geotechnical survey
 Contamination
 Hydrogeology
 Mining
 Terrain analysis
 Waste management

Water

Supply & storage
 Flooding
 Stormwater & drainage
 Wetlands
 Water quality
 Irrigation
 Water sensitive design

Wastewater

Treatment
 Re-use
 Biosolids
 Design
 Management
 Monitoring
 Construction

Civil

Earthworks
 Excavations
 Pipelines
 Roads
 Pavements
 Parking
 Structures

Head Office

Suite 201, 20 George St
 Hornsby NSW 2077, Australia
Ph 02 9476 9999 Fax 02 9476 8767
 > mail@martens.com.au
www.martens.com.au
 MARTENS & ASSOCIATES P/L
 ABN 85 070 240 890 ACN 070 240 890

2. Review of monitoring results against POEO Act Environmental Protection License 5888 conditions

1. Effluent 1 (Eff1) (Monitoring Point 2)

Laboratory results were reviewed against License 5888 conditions for Eff1 (Monitoring Point 2), results are summarised in Table 1. Conclusions regarding Eff1 are:

- Laboratory results for Eff1 indicate license conditions were exceeded for faecal coliforms during October.
- Laboratory results for Eff1 indicate license conditions were exceeded for nitrogen total during October. MA notes that this is still below Nutrient Modelling calculated in P2108127JR11, Section 4.2.
- Laboratory results for Eff1 indicate Phosphorus (total) exceeded the 50 percentile concentration limit for October.
- Laboratory results for Eff1 indicate TSS exceeded licence 5888 conditions for October.
- MA recommends contacting the service contractor for inspection of the system to determine observed exceedances in Table 1.
- All other laboratory results for Eff1 were within license conditions during October.

Table 1: Review of monitoring results for Eff1 against License 5888 conditions.

Chemical	Units	License 5888 Conditions – Eff1 (Point 2)			Sampling Date 2024	
		50 percentile concentration limit	90 percentile concentration limit	100 percentile concentration limit	24 October Results	Complies?
BOD	mg/L		20	30	7	✓
Faecal coliforms (FC)	CFU/100 mL	25		150	31	✗
Nitrogen (total)	mg/L		10	15	18.6	✗
Oil and grease	mg/L	1.5		5	<1	✓
pH	pH units			6.5 – 8.5	8.17	✓
Phosphorous (total)	mg/L	5.5		10	8.36	✗
Total suspended solids (TSS)	mg/L		10	20	45	✗

3. Reuse Effluent (Eff2) (Monitoring Point 6)

Laboratory results were reviewed against License 5888 conditions for Eff2 (Monitoring Point 6). Conclusions regarding Eff2 are:

- Laboratory results for Eff2 (Monitoring Point 6) indicate no sample was collected.

From discussion with site operators MA understands the following:

- Chlorine dosing has been automated.
- All effluent is being pumped into a sewage tanker and taken offsite by a licensed contractor.
- Anoxic tank taken offline and used for storage (200kL).
- No irrigation fields or reuse are currently in use. Irrigation fields will be used once consistent compliance results and approval are achieved from NSW EPA.
- Eff1 samples are taken from treated effluent line into anoxic tank.

If Eff1 and Eff2 are no longer being used and is instead taken offsite by a licensed contractor, any exceedances mentioned above are irrelevant to the conditions of licence 5888.

We recommend that prior to effluent disposal all wastewater treatment and storage tanks are serviced and verified as operating in accordance with License 5888 requirements.

4. Review of monitored parameters

During October sampling period ground water monitoring points SW1 – SW3 were sampled.

Surface water monitoring results were reviewed for October 2024.

All laboratory results for Surface water monitoring for October 2024 are generally consistent with previous reported periods and will continue to be monitored.

5. Drinking water supply tank testing

Laboratory results were reviewed against National Drinking Water Quality Standards for drinking water at multiple tested tanks:

- All sample locations were within the standards for faecal coliforms with results (<1 CFU/100ml) for October 2024.
- All sample locations were within the standards for *E. coli* with results (<1 CFU/100mL) for October 2024.
- Beach Front Tank and Top Toilet Tank were not sampled due to "Tank not in use".

Any questions or concerns please contact our office.

**For and on behalf of
MARTENS & ASSOCIATES PTY LTD**



TRYSTAN RICHARDS
Environmental Consultant

DAILY MONITORING RECORD - MERRY BEACH CARAVAN PARK SEWAGE TREATMENT AND RE-USE SCHEME

Start Date:

30/9/24

Finish Date:

6/10/24

Day of Week	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
Time of Readings	7:30.	8:25.	9:45	9:08	8:35	9:30	9:20
Meter 1 Reading MAGFLOW (L)	12.15.	12.24.	12.29	12.34	12.40	12.49	12.60
Meter 2 Reading (KL) - Non-Potable RU	0.00.	0.00	0.00	0.00	0.00	0.00	0.00
Meter 3 Reading (KL) - Irrigation	12.43	13.31	14.10	14.51	15.28	16.03	17.19
Meter 4 Reading (KL) - NPWS	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Meter 5 Reading (KL) - DLWC	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Pump Well Effluent Appearance	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY
STP Status	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED
UV Lamp Status	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED
Chlorination System Status	OK / FAULTY	OK / FAULTY	OK / FAULTY	OK / FAULTY	OK / FAULTY	OK / FAULTY	OK / FAULTY
Irrigation Field Status	OK / WET / PONDING	OK / WET / PONDING	OK / WET / PONDING	OK / WET / PONDING	OK / WET / PONDING	OK / WET / PONDING	OK / WET / PONDING
Weather Conditions	SUNNY / CLOUDY / RAIN	SUNNY / CLOUDY / RAIN	SUNNY / CLOUDY / RAIN	SUNNY / CLOUDY / RAIN	SUNNY / CLOUDY / RAIN	SUNNY / CLOUDY / RAIN	SUNNY / CLOUDY / RAIN
Dissolved Oxygen in IDEA reactor (mg/L)	0.00	0.00	0.00	0.00	0.00	0.00	0.00
pH in IDEA reactor / Effluent PW	6.79	7.12	7.23	7.15	7.11	7.37	7.62
Total Alkalinity in IDEA Reactor (mg/L)		310 mg/l.					
30 minute sludge volume (%)		70%					
Chlorine (residual) onsite testing Eff2 (once per week)							
Initials	LOVE.	LOVE.	BRIAN.	BRIAN	ABE	BRIAN	BRIAN

DAILY MONITORING RECORD - MERRY BEACH CARAVAN PARK SEWAGE TREATMENT AND RE-USE SCHEME

Start Date:

7/10/24

Finish Date:

13/10/24

Day of Week	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
Time of Readings	10.25.	7.40.	7.50	9.30	10.40	9.40	7.25
Meter 1 Reading MAGFLOW (L)	12.73	12.76.	12.85.	12.90	12.98	13.03	13.08
Meter 2 Reading (KL) - Non-Potable RU	0.00	0.00.	0.00	0.00	0.00	0.00	0.00.
Meter 3 Reading (KL) - Irrigation	18.39	1918	1975.	2031	2109	2146	2221
Meter 4 Reading (KL) - NPWS	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Meter 5 Reading (KL) - DLWC	0.00	0.00.	0.00	0.00	0.00	0.00	0.00
Pump Well Effluent Appearance	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY
STP Status	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED
UV Lamp Status	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED
Chlorination System Status	OK / FAULTY	OK / FAULTY	OK / FAULTY	OK / FAULTY	OK / FAULTY	OK / FAULTY	OK / FAULTY
Irrigation Field Status	OK / WET / PONDING / RAIN	OK / WET / PONDING / RAIN	OK / WET / PONDING / RAIN	OK / WET / PONDING / RAIN	OK / WET / PONDING / RAIN	OK / WET / PONDING / RAIN	OK / WET / PONDING / RAIN
Weather Conditions	SUNNY / CLOUDY / RAIN	SUNNY / CLOUDY / RAIN	SUNNY / CLOUDY / RAIN	SUNNY / CLOUDY / RAIN	SUNNY / CLOUDY / RAIN	SUNNY / CLOUDY / RAIN	SUNNY / CLOUDY / RAIN
Dissolved Oxygen in IDEA reactor (mg/L)	0.00	0.00.	0.00	0.00	0.00	0.00	0.00
pH in IDEA reactor / Effluent PW	7.831	7.661	7.64	7.651	7.67	7.62	7.621
Total Alkalinity in IDEA Reactor (mg/L)	498 mg/l	> 500 mg/l		> 500 mg/l			> 500 mg/l
30 minute sludge volume (%)	90%	70%		58%			60%
Chlorine (residual) onsite testing Eff2 (once per week)							
Initials	LUKE.	LUKE.	LUKE	LUKE	BRIAN	BRIAN	LUKE.

OKAY

DAILY MONITORING RECORD - MERRY BEACH CARAVAN PARK SEWAGE TREATMENT AND RE-USE SCHEME

Start Date: 14/10/24.

Finish Date: 20/10/24.

Day of Week	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
Time of Readings	7.45	7.56.	8.40	9.55	7.29	7.25	7.30.
Meter 1 Reading MAGFLOW (L)	13.11.	13.13	13.16	13.17	13.20.	13.25	13.31
Meter 2 Reading (KL) - Non-Potable RU	0.00.	0.00.	0.00	0.00	0.00.	0.00	0.00.
Meter 3 Reading (KL) - Irrigation	22.61	22.61.	22.99	22.99	23.35	23.73	24.53
Meter 4 Reading (KL) - NPWS	0.00	0.00	0.00	0.00	0.00	0.00	0.00.
Meter 5 Reading (KL) - DLWC	0.00.	0.00	0.00	0.00	0.00.	0.00	0.00.
Pump Well Effluent Appearance	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY
STP Status	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED
UV Lamp Status	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED
Chlorination System Status	OK / FAULTY	OK / FAULTY	OK / FAULTY	OK / FAULTY	OK / FAULTY	OK / FAULTY	OK / FAULTY
Irrigation Field Status	OK / WET / PONDING	OK / WET / PONDING	OK / WET / PONDING	OK / WET / PONDING	OK / WET / PONDING	OK / WET / PONDING	OK / WET / PONDING
Weather Conditions	SUNNY / CLOUDY / RAIN	SUNNY / CLOUDY / RAIN	SUNNY / CLOUDY / RAIN	SUNNY / CLOUDY / RAIN	SUNNY / CLOUDY / RAIN	SUNNY / CLOUDY / RAIN	SUNNY / CLOUDY / RAIN
Dissolved Oxygen in IDEA reactor (mg/L)	0.00	0.00	0.63	1.69	0.68	0.00	0.00
pH in IDEA reactor / Effluent PW	7.59	7.54	7.68	7.79	7.68	7.64	7.60
Total Alkalinity in IDEA Reactor (mg/L)	> 500 mg/l.				> 500 mg/l.	> 500 mg/l.	
30 minute sludge volume (%)	50%				45%	55%	
Chlorine (residual) onsite testing Eff2 (once per week)							
Initials	CRAIG.	CRAIG	BRIAN	BRIAN	CRAIG. & LUKE	LUKE.	LUKE.

DAILY MONITORING RECORD - MERRY BEACH CARAVAN PARK SEWAGE TREATMENT AND RE-USE SCHEME

P0501061JC01_V4 STP diary record sheet.docx

Start Date:

21-10-2024

Finish Date: 27-10-24

Day of Week	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
Time of Readings	7.40	8.05	7.20	9.35	7.55	7.35	7.45
Meter 1 Reading MAGFLOW (l)	13.34	13.37	13.39	13.41	13.42	13.46	13.51
Meter 2 Reading (KL) - Non-Potable RU	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Meter 3 Reading (KL) - Irrigation	2490	2529	25.31	25.86	2618	2622	2695
Meter 4 Reading (KL) - NPWS	0.00	0.00	0.00	0.00	0.00	110.484	110.547
Meter 5 Reading (KL) - DLWC	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Pump Well Effluent Appearance	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY	CLEAR / CLOUDY / GREY
STP Status	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED
UV Lamp Status	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED	OK / ALARMED
Chlorination System Status	OK / FAULTY	OK / FAULTY	OK / FAULTY	OK / FAULTY	OK / ALARMED	OK / ALARMED	OK / ALARMED
Irrigation Field Status	OK / WET / PONDING	OK / WET / PONDING	OK / WET / PONDING	OK / WET / PONDING	OK / FAULTY	OK / FAULTY	OK / FAULTY
Weather Conditions	SUNNY / CLOUDY / RAIN	SUNNY / CLOUDY / RAIN	SUNNY / CLOUDY / RAIN	SUNNY / CLOUDY / RAIN	OK / WET / PONDING	OK / WET / PONDING	OK / WET / PONDING
Dissolved Oxygen in IDEA reactor (mg/L)	0.00	0.00	0.00	0.32	0.52	1.16	1.88
pH in IDEA reactor / Effluent PW	7.67	7.67	7.67	7.76	7.75	7.53	7.53
Total Alkalinity in IDEA Reactor (mg/L)		7500 mg/l					
30 minute sludge volume (%)		67%					
Chlorine (residual) onsite testing Eff2 (once per week)					48%		437 mg/l
Initials	CRAG	CRAG	CRAG	BRAN	LOVE	LOVE	LOVE

BACK FIELD

BACK FIELD IRRIGATION IST RUN 26/10/24 - 7.30am.

ALUM DOSING FIXED 25/10/24.



SAMPLE RECEIPT NOTIFICATION (SRN)

Work Order : **EW2404886**

Client	: Ingenia Holidays Merry Beach	Laboratory	: Environmental Division NSW South Coast
Contact	: Gray Taylor	Contact	: Aneta Prosaroski
Address	: Merry Beach Road, Kioloa 2539	Address	: 1/19 Ralph Black Dr, North Wollongong 2500 NSW Australia
E-mail	: gtaylor@martens.com.au	E-mail	: Aneta.Prosaroski@ALSGlobal.com
Telephone	: 02 9476 9999	Telephone	: 02 42253125
Facsimile	: ----	Facsimile	: W 02 42253128 N 02 44232083
Project	: Merry Beach Monitoring - Oct 2024	Page	: 1 of 4
Order number	: P2108127	Quote number	: EW2024INGMER0001 (EW24INGMER0001)
C-O-C number	: ----	QC Level	: NEPM 2013 B3 & ALS QC Standard
Site	: ----		
Sampler	: Tom Roose		

Dates

Date Samples Received	: 24-Oct-2024 17:00	Issue Date	: 24-Oct-2024
Client Requested Due Date	: 01-Nov-2024	Scheduled Reporting Date	: 01-Nov-2024

Delivery Details

Mode of Delivery	: Sampled By ALS	Security Seal	: Not Available
No. of coolers/boxes	: ----	Temperature	: 4.0, 3.6, 3.9
Receipt Detail	:	No. of samples received / analysed	: 2 / 2

General Comments

- This report contains the following information:
 - Sample Container(s)/Preservation Non-Compliances
 - Summary of Sample(s) and Requested Analysis
 - Proactive Holding Time Report
 - Requested Deliverables
- **Sample Disposal - Aqueous (3 weeks), Solid (2 months) from receipt of samples.**
- **Please direct any queries you have regarding this work order to the above ALS laboratory contact.**
- **Unless otherwise stated, analytical work for this work order will be conducted at ALS Sydney, NATA accreditation no. 825, site no. 10911.**
- Please be aware that APHA/NEPM recommends water and soil samples be chilled to less than or equal to 6°C for chemical analysis, and less than or equal to 10°C but unfrozen for Microbiological analysis. Where samples are received above this temperature, it should be taken into consideration when interpreting results. Refer to ALS EnviroMail 85 for ALS recommendations of the best practice for chilling samples after sampling and for maintaining a cool temperature during transit.
- **Please refer to the Proactive Holding Time Report table below which summarises breaches of recommended holding times that have occurred prior to samples/instructions being received at the laboratory. The laboratory will process these samples unless instructions are received from you indicating you do not wish to proceed. The absence of this summary table indicates that all samples have been received within the recommended holding times for the analysis requested.**



Sample Container(s)/Preservation Non-Compliances

All comparisons are made against pretreatment/preservation AS, APHA, USEPA standards.

- No sample container / preservation non-compliance exists.

Summary of Sample(s) and Requested Analysis

Some items described below may be part of a laboratory process necessary for the execution of client requested tasks. Packages may contain additional analyses, such as the determination of moisture content and preparation tasks, that are included in the package.

If no sampling time is provided, the sampling time will default 00:00 on the date of sampling. If no sampling date is provided, the sampling date will be assumed by the laboratory and displayed in brackets without a time component

Matrix: **WATER**

Laboratory sample ID	Sampling date / time	Sample ID	WATER - EA025H Suspended Solids - Standard Level	WATER - EK055G Ammonia as N By Discrete Analyser	WATER - EN67 PK - pH Field Tests - pH - ALS Wollongong	WATER - EP020 LL Oil and Grease Low Level	WATER - EP030 BOD	WATER - MW006 (FC) Thermotolerant Coliforms by Membrane Filtration	WATER - NT-11 Total Nitrogen and Total Phosphorus
EW2404886-001	24-Oct-2024 00:00	884/Eff1	✓	✓	✓	✓	✓	✓	✓
EW2404886-003	24-Oct-2024 00:00	Influent	✓	✓	✓	✓	✓		✓

Matrix: **WATER**

Laboratory sample ID	Sampling date / time	Sample ID	WATER - MW006 (FC & Ec) Thermotolerant Coliforms & E.coli by Membrane
EW2404886-003	24-Oct-2024 00:00	Influent	✓

Proactive Holding Time Report

Sample(s) have been received within the recommended holding times for the requested analysis.



Requested Deliverables

ALL INVOICES FOR MERRY BEACH

- *AU Certificate of Analysis - NATA (COA)	Email	KBourke@ingeniacommunities.com.au
- *AU Interpretive QC Report - DEFAULT (Anon QCI Rep) (QCI)	Email	KBourke@ingeniacommunities.com.au
- *AU QC Report - DEFAULT (Anon QC Rep) - NATA (QC)	Email	KBourke@ingeniacommunities.com.au
- A4 - AU Sample Receipt Notification - Environmental HT (SRN)	Email	KBourke@ingeniacommunities.com.au
- A4 - AU Tax Invoice (INV)	Email	KBourke@ingeniacommunities.com.au
- Chain of Custody (CoC) (COC)	Email	KBourke@ingeniacommunities.com.au
- EDI Format - XTab (XTAB)	Email	KBourke@ingeniacommunities.com.au

Emily Jongsma

- *AU Certificate of Analysis - NATA (COA)	Email	ejongsma@martens.com.au
- *AU Interpretive QC Report - DEFAULT (Anon QCI Rep) (QCI)	Email	ejongsma@martens.com.au
- *AU QC Report - DEFAULT (Anon QC Rep) - NATA (QC)	Email	ejongsma@martens.com.au
- A4 - AU Sample Receipt Notification - Environmental HT (SRN)	Email	ejongsma@martens.com.au
- Chain of Custody (CoC) (COC)	Email	ejongsma@martens.com.au
- EDI Format - XTab (XTAB)	Email	ejongsma@martens.com.au

Gray Taylor

- *AU Certificate of Analysis - NATA (COA)	Email	gtaylor@martens.com.au
- *AU Interpretive QC Report - DEFAULT (Anon QCI Rep) (QCI)	Email	gtaylor@martens.com.au
- *AU QC Report - DEFAULT (Anon QC Rep) - NATA (QC)	Email	gtaylor@martens.com.au
- A4 - AU Sample Receipt Notification - Environmental HT (SRN)	Email	gtaylor@martens.com.au
- Chain of Custody (CoC) (COC)	Email	gtaylor@martens.com.au
- EDI Format - XTab (XTAB)	Email	gtaylor@martens.com.au

Mail Martens

- *AU Certificate of Analysis - NATA (COA)	Email	mail@martens.com.au
- *AU Interpretive QC Report - DEFAULT (Anon QCI Rep) (QCI)	Email	mail@martens.com.au
- *AU QC Report - DEFAULT (Anon QC Rep) - NATA (QC)	Email	mail@martens.com.au
- A4 - AU Sample Receipt Notification - Environmental HT (SRN)	Email	mail@martens.com.au
- Chain of Custody (CoC) (COC)	Email	mail@martens.com.au
- EDI Format - XTab (XTAB)	Email	mail@martens.com.au

Manager (Reports & Invoice)

- *AU Certificate of Analysis - NATA (COA)	Email	merrybeachmgr@ingeniaholidays.com.au
- *AU Interpretive QC Report - DEFAULT (Anon QCI Rep) (QCI)	Email	merrybeachmgr@ingeniaholidays.com.au
- *AU QC Report - DEFAULT (Anon QC Rep) - NATA (QC)	Email	merrybeachmgr@ingeniaholidays.com.au
- A4 - AU Sample Receipt Notification - Environmental HT (SRN)	Email	merrybeachmgr@ingeniaholidays.com.au
- A4 - AU Tax Invoice (INV)	Email	merrybeachmgr@ingeniaholidays.com.au
- Chain of Custody (CoC) (COC)	Email	merrybeachmgr@ingeniaholidays.com.au
- EDI Format - XTab (XTAB)	Email	merrybeachmgr@ingeniaholidays.com.au

Payables

- A4 - AU Tax Invoice (INV)	Email	payables@ingeniacommunities.com.au
-----------------------------	-------	------------------------------------

Trystan Richards

- *AU Certificate of Analysis - NATA (COA)	Email	trichards@martens.com.au
- *AU Interpretive QC Report - DEFAULT (Anon QCI Rep) (QCI)	Email	trichards@martens.com.au
- *AU QC Report - DEFAULT (Anon QC Rep) - NATA (QC)	Email	trichards@martens.com.au
- A4 - AU Sample Receipt Notification - Environmental HT (SRN)	Email	trichards@martens.com.au
- Chain of Custody (CoC) (COC)	Email	trichards@martens.com.au
- EDI Format - XTab (XTAB)	Email	trichards@martens.com.au

Issue Date : 24-Oct-2024
Page : 4 of 4
Work Order : EW2404886 Amendment 0
Client : Ingenia Holidays Merry Beach



Inter-Laboratory Testing

Analysis conducted by ALS Sydney, NATA accreditation no. 825, site no. 10911 (Chemistry / Biology).

- (WATER) EK055G: Ammonia as N by Discrete Analyser
 - (WATER) EK067G: Total Phosphorus as P by Discrete Analyser
 - (WATER) EK062G: Total Nitrogen as N (TKN + NOx) by Discrete Analyser
 - (WATER) EK061G: Total Kjeldahl Nitrogen By Discrete Analyser
 - (WATER) EK059G: Nitrite plus Nitrate as N (NOx) by Discrete Analyser
 - (WATER) EA025: Total Suspended Solids dried at 104 ± 2°C
 - (WATER) EP020: Oil and Grease (O&G)
 - (WATER) EP030: Biochemical Oxygen Demand (BOD)
 - (WATER) MW006: Thermotolerant Coliforms & E.coli by MF
-

WATER ANALYSIS CHAIN OF CUSTODY

Project: Merry Beach Monitoring – October 2024	Laboratory: ALS (Australian Laboratory Services)	Delivery Details	
Sampling Date:	Results Required by:	Address: 4/13 Geary Place, North Nowra, NSW 2541	Dispatch Date:
Our reference: P2108127	Our Contact: Gray Taylor	Contact:	Shipment Method:
		Phone: (02) 4423 2063	
		Facsimile: (02) 4423 2083	

Sample ID	Number of Containers	Analysis Required (X)												
		pH	Conductivity	Suspended Solids	BOD ₅	Phosphorous (total)	Nitrogen (total)	TKN	Ammonia	NO _x	Faecal Col.	Enterococci	Oil and Grease	E. Coli
884/EF#1		X		X	X	X	X	X	X	X	X			
884/EF#2		X		X									X	
Influent		X		X	X	X	X	X	X	X	X			X

Notes: Fax (02 9476 8767) and email (gtaylor@martens.com.au; trichards@martens.com.au; mail@martens.com.au; Young.dete7@gmail.com and merrybeachmgr@ingeniaholidays.com.au) results as soon as available. originals of laboratory reports to be posted to Merry Beach Caravan Park, KILOLA, NSW, 2539.

MSG
MSG
temp 4.0, 3.6, 3.9.

1030
 N/A
 1045

Environmental Division
 Wollongong
 Work Order Reference
EW2404886



Telephone : 02 42253125



Environmental Engineering – Sustainable Solutions

- Environmental**
 - ES & REF
 - Streams & rivers
 - Coastal
 - Groundwater
 - Catchments
 - Bushfire
 - Monitoring
- Geotechnics**
 - Foundations
 - Geotechnical survey
 - Contamination
 - Excavations
 - Hydrogeology
 - Terrain analysis
 - Waste management
- Water**
 - Supply & storage
 - Flooding
 - Stormwater & drainage
 - Wetlands
 - Water quality
 - Irrigation
 - Water sensitive design
- Wastewater**
 - Treatment
 - Re-use
 - Biosolids
 - Design
 - Management
 - Monitoring
 - Construction

Head Office
 Suite 201, 20 George Street
 Hornsby NSW 2077, Australia
Ph 02 9476 9999 Fax 02 9476 8767
 > mail@martens.com.au
 www.martens.com.au
 MARTENS & ASSOCIATES P/L
 ABN 85 070 240 890 ACN 070 240 890



CERTIFICATE OF ANALYSIS

Work Order	: EW2404886	Page	: 1 of 4
Client	: Ingenia Holidays Merry Beach	Laboratory	: Environmental Division NSW South Coast
Contact	: Gray Taylor	Contact	: Aneta Prosaroski
Address	: Merry Beach Road, Kioloa 2539	Address	: 1/19 Ralph Black Dr, North Wollongong 2500 NSW Australia
Telephone	: 02 9476 9999	Telephone	: 02 42253125
Project	: Merry Beach Monitoring - Oct 2024	Date Samples Received	: 24-Oct-2024 17:00
Order number	: P2108127	Date Analysis Commenced	: 25-Oct-2024
C-O-C number	: ----	Issue Date	: 01-Nov-2024 16:13
Sampler	: Tom Roose		
Site	: ----		
Quote number	: EW24INGMER0001		
No. of samples received	: 2		
No. of samples analysed	: 2		



This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is carried out in compliance with procedures specified in 21 CFR Part 11.

Signatories	Position	Accreditation Category
Dian Dao	Senior Chemist - Inorganics	Sydney Inorganics, Smithfield, NSW
Prasanna Ganta	Team Leader - Microbiology/Phycology	Sydney Microbiology, Smithfield, NSW



General Comments

The analytical procedures used by ALS have been developed from established internationally recognised procedures such as those published by the USEPA, APHA, AS and NEPM. In house developed procedures are fully validated and are often at the client request.

Where moisture determination has been performed, results are reported on a dry weight basis.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contract for details.

Key : CAS Number = CAS registry number from database maintained by Chemical Abstracts Services. The Chemical Abstracts Service is a division of the American Chemical Society.
LOR = Limit of reporting
^ = This result is computed from individual analyte detections at or above the level of reporting
ø = ALS is not NATA accredited for these tests.
~ = Indicates an estimated value.

- MF = membrane filtration
- CFU = colony forming unit
- MW006 is ALS's internal code and is equivalent to AS4276.5.
- Microbiological Comment: In accordance with ALS work instruction QWI-MIC/04, membrane filtration result is reported an approximate (~) when the count of colonies on the filtered membrane is outside the range of 10 - 100cfu.
- pH performed by ALS Wollongong via in-house method EA005FD and EN67 PK.
- Electrical conductivity performed by ALS Wollongong via in-house method EA010FD and EN67 PK.
- Sampling and groundwater depth measurements completed by ALS Wollongong via inhouse sampling method EN/67.11 Groundwater Sampling. Via Bailer Method.
- Sampling completed by ALS Wollongong in accordance with in-house sampling method EN/67.10 Wastewaters
- Sample collection of Ground Waters by in-house EN67 where the "surface layer of the aquifer was sampled".



Analytical Results

Sub-Matrix: WATER (Matrix: WATER)			Sample ID	884/Eff1	Influent	----	----	----
Sampling date / time			24-Oct-2024 00:00	24-Oct-2024 00:00	----	----	----	
Compound	CAS Number	LOR	Unit	EW2404886-001	EW2404886-003	-----	-----	-----
				Result	Result	----	----	----
EA005P: pH by PC Titrator								
pH Value	----	0.01	pH Unit	8.17	7.83	----	----	----
EA025: Total Suspended Solids dried at 104 ± 2°C								
Suspended Solids (SS)	----	5	mg/L	45	166	----	----	----
EK055G: Ammonia as N by Discrete Analyser								
Ammonia as N	7664-41-7	0.01	mg/L	0.17	44.8	----	----	----
EK059G: Nitrite plus Nitrate as N (NOx) by Discrete Analyser								
Nitrite + Nitrate as N	----	0.01	mg/L	16.4	<0.01	----	----	----
EK061G: Total Kjeldahl Nitrogen By Discrete Analyser								
Total Kjeldahl Nitrogen as N	----	0.1	mg/L	2.2	53.6	----	----	----
EK062G: Total Nitrogen as N (TKN + NOx) by Discrete Analyser								
[^] Total Nitrogen as N	----	0.1	mg/L	18.6	53.6	----	----	----
EK067G: Total Phosphorus as P by Discrete Analyser								
Total Phosphorus as P	----	0.01	mg/L	8.36	8.00	----	----	----
EP020: Oil and Grease (O&G)								
Oil & Grease	----	1.0	mg/L	<1.0	19.3	----	----	----
EP030: Biochemical Oxygen Demand (BOD)								
Biochemical Oxygen Demand	----	2	mg/L	7	109	----	----	----
MW006: Thermotolerant Coliforms & E.coli by MF								
Thermotolerant Coliforms	----	1	CFU/100mL	31	55000000	----	----	----
<i>Escherichia coli</i>	----	1	CFU/100mL	----	49000000	----	----	----



Inter-Laboratory Testing

Analysis conducted by ALS Sydney, NATA accreditation no. 825, site no. 10911 (Chemistry / Biology).

(WATER) EP030: Biochemical Oxygen Demand (BOD)

(WATER) EK055G: Ammonia as N by Discrete Analyser

(WATER) MW006: Thermotolerant Coliforms & E.coli by MF

(WATER) EK067G: Total Phosphorus as P by Discrete Analyser

(WATER) EK062G: Total Nitrogen as N (TKN + NO_x) by Discrete Analyser

(WATER) EK061G: Total Kjeldahl Nitrogen By Discrete Analyser

(WATER) EK059G: Nitrite plus Nitrate as N (NO_x) by Discrete Analyser

(WATER) EA025: Total Suspended Solids dried at 104 ± 2°C

(WATER) EP020: Oil and Grease (O&G)

(WATER) EA005P: pH by PC Titrator



QUALITY CONTROL REPORT

Work Order	: EW2404886	Page	: 1 of 4
Client	: Ingenia Holidays Merry Beach	Laboratory	: Environmental Division NSW South Coast
Contact	: Gray Taylor	Contact	: Aneta Prosaroski
Address	: Merry Beach Road, Kioloa 2539	Address	: 1/19 Ralph Black Dr, North Wollongong 2500 NSW Australia
Telephone	: 02 9476 9999	Telephone	: 02 42253125
Project	: Merry Beach Monitoring - Oct 2024	Date Samples Received	: 24-Oct-2024
Order number	: P2108127	Date Analysis Commenced	: 25-Oct-2024
C-O-C number	: ----	Issue Date	: 01-Nov-2024
Sampler	: Tom Roose		
Site	: ----		
Quote number	: EW24INGMER0001		
No. of samples received	: 2		
No. of samples analysed	: 2		



This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. This document shall not be reproduced, except in full.

This Quality Control Report contains the following information:

- Laboratory Duplicate (DUP) Report; Relative Percentage Difference (RPD) and Acceptance Limits
- Method Blank (MB) and Laboratory Control Spike (LCS) Report; Recovery and Acceptance Limits
- Matrix Spike (MS) Report; Recovery and Acceptance Limits

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is carried out in compliance with procedures specified in 21 CFR Part 11.

Signatories	Position	Accreditation Category
Dian Dao	Senior Chemist - Inorganics	Sydney Inorganics, Smithfield, NSW
Prasanna Ganta	Team Leader - Microbiology/Phycology	Sydney Microbiology, Smithfield, NSW



General Comments

The analytical procedures used by ALS have been developed from established internationally recognised procedures such as those published by the USEPA, APHA, AS and NEPM. In house developed procedures are fully validated and are often at the client request.

Where moisture determination has been performed, results are reported on a dry weight basis.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis. Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Key :
 Anonymous = Refers to samples which are not specifically part of this work order but formed part of the QC process lot
 CAS Number = CAS registry number from database maintained by Chemical Abstracts Services. The Chemical Abstracts Service is a division of the American Chemical Society.
 LOR = Limit of reporting
 RPD = Relative Percentage Difference
 # = Indicates failed QC
 * = The final LOR has been raised due to dilution or other sample specific cause; adjusted LOR is shown in brackets. The duplicate ranges for Acceptable RPD% are applied to the final LOR where applicable.

Laboratory Duplicate (DUP) Report

The quality control term Laboratory Duplicate refers to a randomly selected intralaboratory split. Laboratory duplicates provide information regarding method precision and sample heterogeneity. The permitted ranges for the Relative Percent Deviation (RPD) of Laboratory Duplicates are specified in ALS Method QWI-EN/38 and are dependent on the magnitude of results in comparison to the level of reporting: Result < 10 times LOR: No Limit; Result between 10 and 20 times LOR: 0% - 50%; Result > 20 times LOR: 0% - 20%.

Sub-Matrix: **WATER**

				Laboratory Duplicate (DUP) Report					
Laboratory sample ID	Sample ID	Method: Compound	CAS Number	LOR	Unit	Original Result	Duplicate Result	RPD (%)	Acceptable RPD (%)
EA005P: pH by PC Titrator (QC Lot: 6148678)									
ES2434797-001	Anonymous	EA005-P: pH Value	----	0.01	pH Unit	7.41	7.36	0.7	0% - 20%
EA025: Total Suspended Solids dried at 104 ± 2°C (QC Lot: 6155647)									
ES2434806-001	Anonymous	EA025H: Suspended Solids (SS)	----	5	mg/L	327	294	10.4	0% - 20%
ES2434873-001	Anonymous	EA025H: Suspended Solids (SS)	----	5	mg/L	9	7	28.6	No Limit
ES2434945-003	Anonymous	EA025H: Suspended Solids (SS)	----	5	mg/L	<5	<5	0.0	No Limit
ES2435124-006	Anonymous	EA025H: Suspended Solids (SS)	----	5	mg/L	<5	<5	0.0	No Limit
EK055G: Ammonia as N by Discrete Analyser (QC Lot: 6153557)									
ES2435101-001	Anonymous	EK055G: Ammonia as N	7664-41-7	0.01 (0.10)*	mg/L	757	755	0.4	0% - 20%
EK059G: Nitrite plus Nitrate as N (NOx) by Discrete Analyser (QC Lot: 6153556)									
ES2434873-001	Anonymous	EK059G: Nitrite + Nitrate as N	----	0.01	mg/L	0.68	0.69	0.0	0% - 20%
EK061G: Total Kjeldahl Nitrogen By Discrete Analyser (QC Lot: 6153553)									
ES2434897-001	Anonymous	EK061G: Total Kjeldahl Nitrogen as N	----	0.1 (1.0)*	mg/L	63.7	58.7	8.1	0% - 20%
EK067G: Total Phosphorus as P by Discrete Analyser (QC Lot: 6153552)									
ES2434853-001	Anonymous	EK067G: Total Phosphorus as P	----	0.01 (0.02)*	mg/L	8.01	7.80	2.7	0% - 20%
ES2434897-001	Anonymous	EK067G: Total Phosphorus as P	----	0.01 (0.02)*	mg/L	9.96	10.1	1.0	0% - 20%
EP030: Biochemical Oxygen Demand (BOD) (QC Lot: 6146357)									
ES2434853-001	Anonymous	EP030: Biochemical Oxygen Demand	----	2	mg/L	3920	4150	5.8	0% - 20%



Method Blank (MB) and Laboratory Control Sample (LCS) Report

The quality control term Method / Laboratory Blank refers to an analyte free matrix to which all reagents are added in the same volumes or proportions as used in standard sample preparation. The purpose of this QC parameter is to monitor potential laboratory contamination. The quality control term Laboratory Control Sample (LCS) refers to a certified reference material, or a known interference free matrix spiked with target analytes. The purpose of this QC parameter is to monitor method precision and accuracy independent of sample matrix. Dynamic Recovery Limits are based on statistical evaluation of processed LCS.

Sub-Matrix: **WATER**

				Method Blank (MB) Report	Laboratory Control Spike (LCS) Report			
Method: Compound	CAS Number	LOR	Unit	Result	Spike Concentration	Spike Recovery (%)	Acceptable Limits (%)	
						LCS	Low	High
EA005P: pH by PC Titrator (QCLot: 6148678)								
EA005-P: pH Value	----	----	pH Unit	----	4 pH Unit	101	98.8	101
				----	7 pH Unit	100	99.2	101
EA025: Total Suspended Solids dried at 104 ± 2°C (QCLot: 6155647)								
EA025H: Suspended Solids (SS)	----	5	mg/L	<5	150 mg/L	104	83.0	129
				<5	1000 mg/L	96.4	82.0	110
				<5	879 mg/L	99.9	83.0	118
EK055G: Ammonia as N by Discrete Analyser (QCLot: 6153557)								
EK055G: Ammonia as N	7664-41-7	0.01	mg/L	<0.01	0.5 mg/L	112	90.0	114
EK059G: Nitrite plus Nitrate as N (NOx) by Discrete Analyser (QCLot: 6153556)								
EK059G: Nitrite + Nitrate as N	----	0.01	mg/L	<0.01	0.5 mg/L	102	91.0	113
EK061G: Total Kjeldahl Nitrogen By Discrete Analyser (QCLot: 6153553)								
EK061G: Total Kjeldahl Nitrogen as N	----	0.1	mg/L	<0.1	10 mg/L	85.0	69.0	123
				<0.1	1 mg/L	88.5	70.0	123
				<0.1	5 mg/L	93.1	70.0	123
EK067G: Total Phosphorus as P by Discrete Analyser (QCLot: 6153552)								
EK067G: Total Phosphorus as P	----	0.01	mg/L	<0.01	4.42 mg/L	124	71.3	126
				<0.01	0.442 mg/L	109	71.3	126
				<0.01	1 mg/L	102	70.0	130
EP020: Oil and Grease (O&G) (QCLot: 6149610)								
EP020: Oil & Grease	----	1	mg/L	<1.0	5000 mg/L	93.6	80.0	120
EP020: Oil and Grease (O&G) (QCLot: 6149611)								
EP020: Oil & Grease	----	1	mg/L	<1.0	5000 mg/L	93.7	80.0	120
EP030: Biochemical Oxygen Demand (BOD) (QCLot: 6146357)								
EP030: Biochemical Oxygen Demand	----	2	mg/L	<2	200 mg/L	92.6	74.0	112

Matrix Spike (MS) Report

The quality control term Matrix Spike (MS) refers to an intralaboratory split sample spiked with a representative set of target analytes. The purpose of this QC parameter is to monitor potential matrix effects on analyte recoveries. Static Recovery Limits as per laboratory Data Quality Objectives (DQOs). Ideal recovery ranges stated may be waived in the event of sample matrix interference.

Sub-Matrix: **WATER**

				Matrix Spike (MS) Report			
				Spike	Spike Recovery (%)	Acceptable Limits (%)	
Laboratory sample ID	Sample ID	Method: Compound	CAS Number	Concentration	MS	Low	High



Sub-Matrix: WATER

				Matrix Spike (MS) Report			
				Spike	SpikeRecovery(%)	Acceptable Limits (%)	
Laboratory sample ID	Sample ID	Method: Compound	CAS Number	Concentration	MS	Low	High
EK055G: Ammonia as N by Discrete Analyser (QCLot: 6153557)							
ES2435101-001	Anonymous	EK055G: Ammonia as N	7664-41-7	0.5 mg/L	# Not Determined	70.0	130
EK059G: Nitrite plus Nitrate as N (NOx) by Discrete Analyser (QCLot: 6153556)							
ES2434873-001	Anonymous	EK059G: Nitrite + Nitrate as N	----	0.5 mg/L	70.6	70.0	130
EK061G: Total Kjeldahl Nitrogen By Discrete Analyser (QCLot: 6153553)							
ES2434887-001	Anonymous	EK061G: Total Kjeldahl Nitrogen as N	----	5 mg/L	# Not Determined	70.0	130
EK067G: Total Phosphorus as P by Discrete Analyser (QCLot: 6153552)							
ES2434887-001	Anonymous	EK067G: Total Phosphorus as P	----	2 mg/L	100	70.0	130



QA/QC Compliance Assessment to assist with Quality Review

Work Order	: EW2404886	Page	: 1 of 5
Client	: Ingenia Holidays Merry Beach	Laboratory	: Environmental Division NSW South Coast
Contact	: Gray Taylor	Telephone	: 02 42253125
Project	: Merry Beach Monitoring - Oct 2024	Date Samples Received	: 24-Oct-2024
Site	: ----	Issue Date	: 01-Nov-2024
Sampler	: Tom Roose	No. of samples received	: 2
Order number	: P2108127	No. of samples analysed	: 2

This report is automatically generated by the ALS LIMS through interpretation of the ALS Quality Control Report and several Quality Assurance parameters measured by ALS. This automated reporting highlights any non-conformances, facilitates faster and more accurate data validation and is designed to assist internal expert and external Auditor review. Many components of this report contribute to the overall DQO assessment and reporting for guideline compliance.

Brief method summaries and references are also provided to assist in traceability.

Summary of Outliers

Outliers : Quality Control Samples

This report highlights outliers flagged in the Quality Control (QC) Report.

- **NO Method Blank value outliers occur.**
- **NO Duplicate outliers occur.**
- **NO Laboratory Control outliers occur.**
- Matrix Spike outliers exist - please see following pages for full details.
- For all regular sample matrices, where applicable to the methodology, **NO** surrogate recovery outliers occur.

Outliers : Analysis Holding Time Compliance

- Analysis Holding Time Outliers exist - please see following pages for full details.

Outliers : Frequency of Quality Control Samples

- **NO Quality Control Sample Frequency Outliers exist.**



Outliers : Quality Control Samples

Duplicates, Method Blanks, Laboratory Control Samples and Matrix Spikes

Matrix: WATER

Compound Group Name	Laboratory Sample ID	Client Sample ID	Analyte	CAS Number	Data	Limits	Comment
Matrix Spike (MS) Recoveries							
EK055G: Ammonia as N by Discrete Analyser	ES2435101--001	Anonymous	Ammonia as N	7664-41-7	Not Determined	----	MS recovery not determined, background level greater than or equal to 4x spike level.
EK061G: Total Kjeldahl Nitrogen By Discrete Analyser	ES2434887--001	Anonymous	Total Kjeldahl Nitrogen as N	----	Not Determined	----	MS recovery not determined, background level greater than or equal to 4x spike level.

Outliers : Analysis Holding Time Compliance

Matrix: WATER

Method	Extraction / Preparation			Analysis			
	Container / Client Sample ID(s)	Date extracted	Due for extraction	Days overdue	Date analysed	Due for analysis	Days overdue
EA005P: pH by PC Titrator							
Clear Plastic Bottle - Natural 884/Eff1,	Influent	----	----	----	28-Oct-2024	24-Oct-2024	4

Analysis Holding Time Compliance

If samples are identified below as having been analysed or extracted outside of recommended holding times, this should be taken into consideration when interpreting results. This report summarizes extraction / preparation and analysis times and compares each with ALS recommended holding times (referencing USEPA SW 846, APHA, AS and NEPM) based on the sample container provided. Dates reported represent first date of extraction or analysis and preclude subsequent dilutions and reruns. A listing of breaches (if any) is provided herein. Holding time for leachate methods (e.g. TCLP) vary according to the analytes reported. Assessment compares the leach date with the shortest analyte holding time for the equivalent soil method. These are: organics 14 days, mercury 28 days & other metals 180 days. A recorded breach does not guarantee a breach for all non-volatile parameters. Holding times for VOC in soils vary according to analytes of interest. Vinyl Chloride and Styrene holding time is 7 days; others 14 days. A recorded breach does not guarantee a breach for all VOC analytes and should be verified in case the reported breach is a false positive or Vinyl Chloride and Styrene are not key analytes of interest/concern.

Matrix: WATER

Evaluation: ✖ = Holding time breach ; ✔ = Within holding time.

Method	Sample Date	Extraction / Preparation			Analysis			
		Container / Client Sample ID(s)	Date extracted	Due for extraction	Evaluation	Date analysed	Due for analysis	Evaluation
EA005P: pH by PC Titrator								
Clear Plastic Bottle - Natural (EA005-P) 884/Eff1,	Influent	24-Oct-2024	----	----	----	28-Oct-2024	24-Oct-2024	✖
EA025: Total Suspended Solids dried at 104 ± 2°C								
Clear Plastic Bottle - Natural (EA025H) 884/Eff1,	Influent	24-Oct-2024	----	----	----	30-Oct-2024	31-Oct-2024	✔
EK055G: Ammonia as N by Discrete Analyser								
Clear Plastic Bottle - Sulfuric Acid (EK055G) 884/Eff1,	Influent	24-Oct-2024	----	----	----	30-Oct-2024	21-Nov-2024	✔
EK059G: Nitrite plus Nitrate as N (NOx) by Discrete Analyser								
Clear Plastic Bottle - Sulfuric Acid (EK059G) 884/Eff1,	Influent	24-Oct-2024	----	----	----	30-Oct-2024	21-Nov-2024	✔



Matrix: **WATER** Evaluation: * = Holding time breach ; ✓ = Within holding time.

Method Container / Client Sample ID(s)	Sample Date	Extraction / Preparation			Analysis		
		Date extracted	Due for extraction	Evaluation	Date analysed	Due for analysis	Evaluation
EK061G: Total Kjeldahl Nitrogen By Discrete Analyser							
Clear Plastic Bottle - Sulfuric Acid (EK061G) 884/Eff1, Influent	24-Oct-2024	30-Oct-2024	21-Nov-2024	✓	30-Oct-2024	21-Nov-2024	✓
EK067G: Total Phosphorus as P by Discrete Analyser							
Clear Plastic Bottle - Sulfuric Acid (EK067G) 884/Eff1, Influent	24-Oct-2024	30-Oct-2024	21-Nov-2024	✓	30-Oct-2024	21-Nov-2024	✓
EP020: Oil and Grease (O&G)							
Amber Jar - Sulfuric Acid or Sodium Bisulfate (EP020 LL) 884/Eff1, Influent	24-Oct-2024	----	----	----	28-Oct-2024	21-Nov-2024	✓
EP030: Biochemical Oxygen Demand (BOD)							
Clear Plastic Bottle - Natural (EP030) 884/Eff1, Influent	24-Oct-2024	----	----	----	25-Oct-2024	26-Oct-2024	✓
MW006: Thermotolerant Coliforms & E.coli by MF							
Sterile Plastic Bottle - Sodium Thiosulfate (MW006) 884/Eff1, Influent	24-Oct-2024	----	----	----	25-Oct-2024	25-Oct-2024	✓



Quality Control Parameter Frequency Compliance

The following report summarises the frequency of laboratory QC samples analysed within the analytical lot(s) in which the submitted sample(s) was(were) processed. Actual rate should be greater than or equal to the expected rate. A listing of breaches is provided in the Summary of Outliers.

Matrix: **WATER** Evaluation: ✖ = Quality Control frequency not within specification ; ✔ = Quality Control frequency within specification.

Quality Control Sample Type	Method	Count		Rate (%)			Quality Control Specification
		QC	Reaular	Actual	Expected	Evaluation	
Laboratory Duplicates (DUP)							
Ammonia as N by Discrete analyser	EK055G	1	3	33.33	10.00	✔	NEPM 2013 B3 & ALS QC Standard
Biochemical Oxygen Demand (BOD)	EP030	1	5	20.00	10.00	✔	NEPM 2013 B3 & ALS QC Standard
Nitrite and Nitrate as N (NOx) by Discrete Analyser	EK059G	1	3	33.33	10.00	✔	NEPM 2013 B3 & ALS QC Standard
pH by Auto Titrator	EA005-P	1	5	20.00	10.00	✔	NEPM 2013 B3 & ALS QC Standard
Suspended Solids (High Level)	EA025H	4	40	10.00	10.00	✔	NEPM 2013 B3 & ALS QC Standard
Total Kjeldahl Nitrogen as N By Discrete Analyser	EK061G	1	10	10.00	10.00	✔	NEPM 2013 B3 & ALS QC Standard
Total Phosphorus as P By Discrete Analyser	EK067G	2	13	15.38	10.00	✔	NEPM 2013 B3 & ALS QC Standard
Laboratory Control Samples (LCS)							
Ammonia as N by Discrete analyser	EK055G	1	3	33.33	5.00	✔	NEPM 2013 B3 & ALS QC Standard
Biochemical Oxygen Demand (BOD)	EP030	1	5	20.00	5.00	✔	NEPM 2013 B3 & ALS QC Standard
Nitrite and Nitrate as N (NOx) by Discrete Analyser	EK059G	1	3	33.33	5.00	✔	NEPM 2013 B3 & ALS QC Standard
Oil and Grease Low Level	EP020 LL	2	21	9.52	5.00	✔	NEPM 2013 B3 & ALS QC Standard
pH by Auto Titrator	EA005-P	2	5	40.00	10.00	✔	NEPM 2013 B3 & ALS QC Standard
Suspended Solids (High Level)	EA025H	5	40	12.50	12.50	✔	NEPM 2013 B3 & ALS QC Standard
Total Kjeldahl Nitrogen as N By Discrete Analyser	EK061G	3	10	30.00	15.00	✔	NEPM 2013 B3 & ALS QC Standard
Total Phosphorus as P By Discrete Analyser	EK067G	3	13	23.08	15.00	✔	NEPM 2013 B3 & ALS QC Standard
Method Blanks (MB)							
Ammonia as N by Discrete analyser	EK055G	1	3	33.33	5.00	✔	NEPM 2013 B3 & ALS QC Standard
Biochemical Oxygen Demand (BOD)	EP030	1	5	20.00	5.00	✔	NEPM 2013 B3 & ALS QC Standard
Nitrite and Nitrate as N (NOx) by Discrete Analyser	EK059G	1	3	33.33	5.00	✔	NEPM 2013 B3 & ALS QC Standard
Oil and Grease Low Level	EP020 LL	2	21	9.52	5.00	✔	NEPM 2013 B3 & ALS QC Standard
Suspended Solids (High Level)	EA025H	2	40	5.00	5.00	✔	NEPM 2013 B3 & ALS QC Standard
Total Kjeldahl Nitrogen as N By Discrete Analyser	EK061G	1	10	10.00	5.00	✔	NEPM 2013 B3 & ALS QC Standard
Total Phosphorus as P By Discrete Analyser	EK067G	1	13	7.69	5.00	✔	NEPM 2013 B3 & ALS QC Standard
Matrix Spikes (MS)							
Ammonia as N by Discrete analyser	EK055G	1	3	33.33	5.00	✔	NEPM 2013 B3 & ALS QC Standard
Nitrite and Nitrate as N (NOx) by Discrete Analyser	EK059G	1	3	33.33	5.00	✔	NEPM 2013 B3 & ALS QC Standard
Total Kjeldahl Nitrogen as N By Discrete Analyser	EK061G	1	10	10.00	5.00	✔	NEPM 2013 B3 & ALS QC Standard
Total Phosphorus as P By Discrete Analyser	EK067G	1	13	7.69	5.00	✔	NEPM 2013 B3 & ALS QC Standard



Brief Method Summaries

The analytical procedures used by the Environmental Division have been developed from established internationally recognized procedures such as those published by the US EPA, APHA, AS and NEPM. In house developed procedures are employed in the absence of documented standards or by client request. The following report provides brief descriptions of the analytical procedures employed for results reported in the Certificate of Analysis. Sources from which ALS methods have been developed are provided within the Method Descriptions.

Analytical Methods	Method	Matrix	Method Descriptions
pH by Auto Titrator	EA005-P	WATER	In house: Referenced to APHA 4500 H+ B. This procedure determines pH of water samples by automated ISE. This method is compliant with NEPM Schedule B(3)
Suspended Solids (High Level)	EA025H	WATER	In house: Referenced to APHA 2540D. A gravimetric procedure employed to determine the amount of 'non-filterable' residue in a aqueous sample. The prescribed GFC (1.2um) filter is rinsed with deionised water, oven dried and weighed prior to analysis. A well-mixed sample is filtered through a glass fibre filter (1.2um). The residue on the filter paper is dried at 104+/-2C . This method is compliant with NEPM Schedule B(3)
Ammonia as N by Discrete analyser	EK055G	WATER	In house: Referenced to APHA 4500-NH3 G Ammonia is determined by direct colorimetry by Discrete Analyser. This method is compliant with NEPM Schedule B(3)
Nitrite and Nitrate as N (NOx) by Discrete Analyser	EK059G	WATER	In house: Referenced to APHA 4500-NO3- F. Combined oxidised Nitrogen (NO2+NO3) is determined by Chemical Reduction and direct colourimetry by Discrete Analyser. This method is compliant with NEPM Schedule B(3)
Total Kjeldahl Nitrogen as N By Discrete Analyser	EK061G	WATER	In house: Referenced to APHA 4500-Norg D (In house). An aliquot of sample is digested using a high temperature Kjeldahl digestion to convert nitrogenous compounds to ammonia. Ammonia is determined colorimetrically by discrete analyser. This method is compliant with NEPM Schedule B(3)
Total Nitrogen as N (TKN + Nox) By Discrete Analyser	EK062G	WATER	In house: Referenced to APHA 4500-Norg / 4500-NO3-. This method is compliant with NEPM Schedule B(3)
Total Phosphorus as P By Discrete Analyser	EK067G	WATER	In house: Referenced to APHA 4500-P H, Jirka et al, Zhang et al. This procedure involves sulphuric acid digestion of a sample aliquot to break phosphorus down to orthophosphate. The orthophosphate reacts with ammonium molybdate and antimony potassium tartrate to form a complex which is then reduced and its concentration measured at 880nm using discrete analyser. This method is compliant with NEPM Schedule B(3)
Oil and Grease Low Level	EP020 LL	WATER	In house: Referenced to APHA 5520 B. Oil & grease is a gravimetric procedure to determine the amount of dissolved or emulsified oil & grease residue in an aqueous sample. The sample is serially extracted three times n-hexane. The resultant extracts are combined, dehydrated and concentrated prior to gravimetric determination. This method is compliant with NEPM Schedule B(3)
Biochemical Oxygen Demand (BOD)	EP030	WATER	In house: Referenced to APHA 5210 B. The 5-Day BOD test provides an empirical measure of the oxygen consumption capacity of a given water. A portion of the sample is diluted into oxygenated, nutrient rich water, and a seed added to begin biological decay. The initial dissolved oxygen content is measured, then the bottle is sealed and incubated for five days. The remaining dissolved oxygen is measured, and from the difference, the demand for oxygen, by biological decay, is determined. This method is compliant with NEPM Schedule B(3).
Thermotolerant Coliforms & E.coli by Membrane Filtration	MW006	WATER	AS 4276.7
Preparation Methods	Method	Matrix	Method Descriptions
TKN/TP Digestion	EK061/EK067	WATER	In house: Referenced to APHA 4500 Norg - D; APHA 4500 P - H. This method is compliant with NEPM Schedule B(3)



SAMPLE RECEIPT NOTIFICATION (SRN)

Work Order : **EW2404887**

Client	: Ingenia Holidays Merry Beach	Laboratory	: Environmental Division NSW South Coast
Contact	: Gray Taylor	Contact	: Aneta Prosaroski
Address	: Merry Beach Road, Kioloa 2539	Address	: 1/19 Ralph Black Dr, North Wollongong 2500 NSW Australia
E-mail	: gtaylor@martens.com.au	E-mail	: Aneta.Prosaroski@ALSGlobal.com
Telephone	: 02 9476 9999	Telephone	: 02 42253125
Facsimile	: ----	Facsimile	: W 02 42253128 N 02 44232083
Project	: Merry Beach Fresh /Drinking Water Monthly	Page	: 1 of 4
Order number	: P0501061	Quote number	: EW2024INGMER0001 (EW24INGMER0001)
C-O-C number	: ----	QC Level	: NEPM 2013 B3 & ALS QC Standard
Site	: ----		
Sampler	: Tom Roose		

Dates

Date Samples Received	: 24-Oct-2024 17:00	Issue Date	: 24-Oct-2024
Client Requested Due Date	: 01-Nov-2024	Scheduled Reporting Date	: 01-Nov-2024

Delivery Details

Mode of Delivery	: Client Drop Off	Security Seal	: Not Available
No. of coolers/boxes	: ----	Temperature	: 5.5, 5.2, 4.8 - Ice present
Receipt Detail	:	No. of samples received / analysed	: 3 / 3

General Comments

- This report contains the following information:
 - Sample Container(s)/Preservation Non-Compliances
 - Summary of Sample(s) and Requested Analysis
 - Proactive Holding Time Report
 - Requested Deliverables
- **Sample Disposal - Aqueous (3 weeks), Solid (2 months) from receipt of samples.**
- **Please direct any queries you have regarding this work order to the above ALS laboratory contact.**
- **Unless otherwise stated, analytical work for this work order will be conducted at ALS Sydney, NATA accreditation no. 825, site no. 10911.**
- Please be aware that APHA/NEPM recommends water and soil samples be chilled to less than or equal to 6°C for chemical analysis, and less than or equal to 10°C but unfrozen for Microbiological analysis. Where samples are received above this temperature, it should be taken into consideration when interpreting results. Refer to ALS EnviroMail 85 for ALS recommendations of the best practice for chilling samples after sampling and for maintaining a cool temperature during transit.
- **Please refer to the Proactive Holding Time Report table below which summarises breaches of recommended holding times that have occurred prior to samples/instructions being received at the laboratory. The laboratory will process these samples unless instructions are received from you indicating you do not wish to proceed. The absence of this summary table indicates that all samples have been received within the recommended holding times for the analysis requested.**



Sample Container(s)/Preservation Non-Compliances

All comparisons are made against pretreatment/preservation AS, APHA, USEPA standards.

- **No sample container / preservation non-compliance exists.**

Summary of Sample(s) and Requested Analysis

Some items described below may be part of a laboratory process necessary for the execution of client requested tasks. Packages may contain additional analyses, such as the determination of moisture content and preparation tasks, that are included in the package.

If no sampling time is provided, the sampling time will default 00:00 on the date of sampling. If no sampling date is provided, the sampling date will be assumed by the laboratory and displayed in brackets without a time component

Matrix: **WATER**

Laboratory sample ID	Sampling date / time	Sample ID	WATER - MW006 (Ec) E. coli by Membrane Filtration	WATER - MW007 Total Coliforms by Membrane Filtration
EW2404887-002	24-Oct-2024 10:50	Creek Tanks	✓	✓
EW2404887-003	24-Oct-2024 10:55	Main tank	✓	✓
EW2404887-005	24-Oct-2024 11:05	Pretty beach tank	✓	✓

Proactive Holding Time Report

Sample(s) have been received within the recommended holding times for the requested analysis.



Requested Deliverables

ALL INVOICES FOR MERRY BEACH

- *AU Certificate of Analysis - NATA (COA)	Email	KBourke@ingeniacommunities.com.au
- *AU Interpretive QC Report - DEFAULT (Anon QCI Rep) (QCI)	Email	KBourke@ingeniacommunities.com.au
- *AU QC Report - DEFAULT (Anon QC Rep) - NATA (QC)	Email	KBourke@ingeniacommunities.com.au
- A4 - AU Sample Receipt Notification - Environmental HT (SRN)	Email	KBourke@ingeniacommunities.com.au
- A4 - AU Tax Invoice (INV)	Email	KBourke@ingeniacommunities.com.au
- Chain of Custody (CoC) (COC)	Email	KBourke@ingeniacommunities.com.au
- EDI Format - XTab (XTAB)	Email	KBourke@ingeniacommunities.com.au

Emily Jongsma

- *AU Certificate of Analysis - NATA (COA)	Email	ejongsma@martens.com.au
- *AU Interpretive QC Report - DEFAULT (Anon QCI Rep) (QCI)	Email	ejongsma@martens.com.au
- *AU QC Report - DEFAULT (Anon QC Rep) - NATA (QC)	Email	ejongsma@martens.com.au
- A4 - AU Sample Receipt Notification - Environmental HT (SRN)	Email	ejongsma@martens.com.au
- Chain of Custody (CoC) (COC)	Email	ejongsma@martens.com.au
- EDI Format - XTab (XTAB)	Email	ejongsma@martens.com.au

Gray Taylor

- *AU Certificate of Analysis - NATA (COA)	Email	gtaylor@martens.com.au
- *AU Interpretive QC Report - DEFAULT (Anon QCI Rep) (QCI)	Email	gtaylor@martens.com.au
- *AU QC Report - DEFAULT (Anon QC Rep) - NATA (QC)	Email	gtaylor@martens.com.au
- A4 - AU Sample Receipt Notification - Environmental HT (SRN)	Email	gtaylor@martens.com.au
- Chain of Custody (CoC) (COC)	Email	gtaylor@martens.com.au
- EDI Format - XTab (XTAB)	Email	gtaylor@martens.com.au

Mail Martens

- *AU Certificate of Analysis - NATA (COA)	Email	mail@martens.com.au
- *AU Interpretive QC Report - DEFAULT (Anon QCI Rep) (QCI)	Email	mail@martens.com.au
- *AU QC Report - DEFAULT (Anon QC Rep) - NATA (QC)	Email	mail@martens.com.au
- A4 - AU Sample Receipt Notification - Environmental HT (SRN)	Email	mail@martens.com.au
- Chain of Custody (CoC) (COC)	Email	mail@martens.com.au
- EDI Format - XTab (XTAB)	Email	mail@martens.com.au

Manager (Reports & Invoice)

- *AU Certificate of Analysis - NATA (COA)	Email	merrybeachmgr@ingeniaholidays.com.au
- *AU Interpretive QC Report - DEFAULT (Anon QCI Rep) (QCI)	Email	merrybeachmgr@ingeniaholidays.com.au
- *AU QC Report - DEFAULT (Anon QC Rep) - NATA (QC)	Email	merrybeachmgr@ingeniaholidays.com.au
- A4 - AU Sample Receipt Notification - Environmental HT (SRN)	Email	merrybeachmgr@ingeniaholidays.com.au
- A4 - AU Tax Invoice (INV)	Email	merrybeachmgr@ingeniaholidays.com.au
- Chain of Custody (CoC) (COC)	Email	merrybeachmgr@ingeniaholidays.com.au
- EDI Format - XTab (XTAB)	Email	merrybeachmgr@ingeniaholidays.com.au

Payables

- A4 - AU Tax Invoice (INV)	Email	payables@ingeniacommunities.com.au
-----------------------------	-------	------------------------------------

Trystan Richards

- *AU Certificate of Analysis - NATA (COA)	Email	trichards@martens.com.au
- *AU Interpretive QC Report - DEFAULT (Anon QCI Rep) (QCI)	Email	trichards@martens.com.au
- *AU QC Report - DEFAULT (Anon QC Rep) - NATA (QC)	Email	trichards@martens.com.au
- A4 - AU Sample Receipt Notification - Environmental HT (SRN)	Email	trichards@martens.com.au
- Chain of Custody (CoC) (COC)	Email	trichards@martens.com.au
- EDI Format - XTab (XTAB)	Email	trichards@martens.com.au

Issue Date : 24-Oct-2024
Page : 4 of 4
Work Order : EW2404887 Amendment 0
Client : Ingenia Holidays Merry Beach



Inter-Laboratory Testing

Analysis conducted by ALS Sydney, NATA accreditation no. 825, site no. 10911 (Chemistry / Biology).

(WATER) MW007: Coliforms by MF

(WATER) MW006: Faecal Coliforms & E.coli by MF

Mandatory Fields

CHAIN OF CUSTODY



CoC #: (if applicable)

CLIENT CODE: IMGMER ***PROJECT MANAGER:** Gray Taylor **SAMPLER:** Peter Young

***CLIENT:** INGENIA HOLIDAYS MERRY BEACH ***PM MOBILE:** 0422 685 594 **0404 455 064**

OFFICE: Merry Beach Rd, Kioloa **ALS QUOTE #:** EW2023INGMER0002 **PURCHASE ORDER NO.:** POS01061

PROJECT NO./PROJECT: Merry Beach Fresh/ Drinking Water Monthly **SITE:**

***INVOICE TO:** payables@ingeniacommunities.com.au, Merrybeachmq@ingeniaholidays.com.au, Kbourke@ingeniacommunities.com.au **CC Invoice to PM:**

***EMAIL:** graylor@martens.com.au; mail@martens.com.au; young.pete7@gmail.com, Merrybeachmq@ingeniaholidays.com.au, Kbourke@ingeniacommunities.com.au, Bconnolly@ingeniaholidays.com.au, Trichards@martens.com.au, ejongsmna@martens.com.au

REPORTS TO: (default to PM if blank)

***STORAGE REQUIREMENTS**

Please check box: Standard Storage Extended Storage

Standard Storage time from receipt of samples: 3 day (+15%) 2 day (+30%) 1 day (+50%)

Waters - 3 weeks
Soils - 2 months

***TURNAROUND**

Please check box: 5+ days (no surcharge) 3 day (+15%) 2 day (+30%) 1 day (+50%)

(Not all tests can be expedited, contact Client Services for more information)

***ANALYSIS REQUIRED**

(NB ALS Quote No. and/or Analysis Some Codes must be listed to attract sub/quoted price)
Where Metals are required, specify Total (unfiltered bottle required) or filtered (filtered bottle required).
Mark an X in the boxes below analysis to indicate the parameter listed above to be tested on that sample.

Comments:

ALS Use Only	Sample ID	Depth	Date/Time	No. Bottles	MATRIX: Soil/Solid(S) Water(W) Sediments (SD), Dust (D), Product (P), Biota (B), Biosolid (BS)	MW006 (Ec) - E.coli	MW007 - Total Coliforms
	Beach Front Tank		24/10/24	1	W	X	X
	Creek Tanks		1050	1	W	X	X
	Main Tank		1055	1	W	X	X
	Pool Shower Tanks		-	1	W	X	X
	Beach Toilet Tank		1105	1	W	X	X

Receipt Detail (Lab Use Only)

Chilling Method: Ice: Ice Bricks: None

Frozen / Melted: Frozen / Thawed:

Signature: *Tom Post* Date/Time: 24/10/24

Received by: *M. S. STATION* Signature: *[Signature]*

Carrier Details: Courier/Post Client

Additional Information: (Comment on hazards - e.g. asbestos, known high contamination)

Lab QC (additional bottles req.): Dup MS

Packaging: (Circle) Hard/Sty # Foam Ekly # Seal/Bag/Other #

Date/Time: 24/10/24 1700

Reinquished by: *Tom Post* Signature: *[Signature]* Date/Time: 24/10/24



Environmental Division
Wollongong
Work Order Reference
EW2404887

Telephone : 02 42253125



CERTIFICATE OF ANALYSIS

Work Order : **EW2404887**
Client : **Ingenia Holidays Merry Beach**
Contact : Gray Taylor
Address : Merry Beach Road,
Kioloa 2539
Telephone : 02 9476 9999
Project : Merry Beach Fresh /Drinking Water Monthly
Order number : P0501061
C-O-C number : ----
Sampler : Tom Roose
Site : ----
Quote number : EW24INGMER0001
No. of samples received : 3
No. of samples analysed : 3

Page : 1 of 2
Laboratory : Environmental Division NSW South Coast
Contact : Aneta Prosaroski
Address : 1/19 Ralph Black Dr, North Wollongong 2500 NSW Australia
Telephone : 02 42253125
Date Samples Received : 24-Oct-2024 17:00
Date Analysis Commenced : 25-Oct-2024
Issue Date : 29-Oct-2024 21:36



This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is carried out in compliance with procedures specified in 21 CFR Part 11.

<i>Signatories</i>	<i>Position</i>	<i>Accreditation Category</i>
Lauren Waters	Microbiology Laboratory Technician	Sydney Microbiology, Smithfield, NSW



Page : 2 of 2
 Work Order : EW2404887
 Client : Ingenia Holidays Merry Beach
 Project : Merry Beach Fresh /Drinking Water Monthly

General Comments

The analytical procedures used by ALS have been developed from established internationally recognised procedures such as those published by the USEPA, APHA, AS and NEPM. In house developed procedures are fully validated and are often at the client request.

Where moisture determination has been performed, results are reported on a dry weight basis.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contract for details.

Key : CAS Number = CAS registry number from database maintained by Chemical Abstracts Services. The Chemical Abstracts Service is a division of the American Chemical Society.
 LOR = Limit of reporting
 ^ = This result is computed from individual analyte detections at or above the level of reporting
 ø = ALS is not NATA accredited for these tests.
 ~ = Indicates an estimated value.

- MF = membrane filtration
- CFU = colony forming unit
- MW006 is ALS's internal code and is equivalent to AS4276.5.
- Microbiological Comment: In accordance with ALS work instruction QWI-MIC/04, membrane filtration result is reported an approximate (~) when the count of colonies on the filtered membrane is outside the range of 10 - 100cfu.
- MW007 is ALS's internal code and is equivalent to AS4276.5.

Analytical Results

Sub-Matrix: WATER
 (Matrix: WATER)

				Sample ID	Creek Tanks	Main tank	Pretty beach tank	----	----
				Sampling date / time	24-Oct-2024 10:50	24-Oct-2024 10:55	24-Oct-2024 11:05	----	----
Compound	CAS Number	LOR	Unit		EW2404887-002	EW2404887-003	EW2404887-005	-----	-----
				Result	Result	Result	----	----	
MW006: Faecal Coliforms & E.coli by MF									
<i>Escherichia coli</i>	----	1	CFU/100mL		<1	<1	<1	----	----
MW007: Coliforms by MF									
Coliforms	----	1	CFU/100mL		<1	<1	<1	----	----

Inter-Laboratory Testing

Analysis conducted by ALS Sydney, NATA accreditation no. 825, site no. 10911 (Chemistry / Biology).

(WATER) MW007: Coliforms by MF

(WATER) MW006: Faecal Coliforms & E.coli by MF



QUALITY CONTROL REPORT

Work Order	: EW2404887	Page	: 1 of 3
Client	: Ingenia Holidays Merry Beach	Laboratory	: Environmental Division NSW South Coast
Contact	: Gray Taylor	Contact	: Aneta Prosaroski
Address	: Merry Beach Road, Kioloa 2539	Address	: 1/19 Ralph Black Dr, North Wollongong 2500 NSW Australia
Telephone	: 02 9476 9999	Telephone	: 02 42253125
Project	: Merry Beach Fresh /Drinking Water Monthly	Date Samples Received	: 24-Oct-2024
Order number	: P0501061	Date Analysis Commenced	: 25-Oct-2024
C-O-C number	: ----	Issue Date	: 29-Oct-2024
Sampler	: Tom Roose		
Site	: ----		
Quote number	: EW24INGMER0001		
No. of samples received	: 3		
No. of samples analysed	: 3		



This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. This document shall not be reproduced, except in full.

This Quality Control Report contains the following information:

- Laboratory Duplicate (DUP) Report; Relative Percentage Difference (RPD) and Acceptance Limits
- Method Blank (MB) and Laboratory Control Spike (LCS) Report; Recovery and Acceptance Limits
- Matrix Spike (MS) Report; Recovery and Acceptance Limits

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is carried out in compliance with procedures specified in 21 CFR Part 11.

Signatories	Position	Accreditation Category
Lauren Waters	Microbiology Laboratory Technician	Sydney Microbiology, Smithfield, NSW



General Comments

The analytical procedures used by ALS have been developed from established internationally recognised procedures such as those published by the USEPA, APHA, AS and NEPM. In house developed procedures are fully validated and are often at the client request.

Where moisture determination has been performed, results are reported on a dry weight basis.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis. Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Key :
Anonymous = Refers to samples which are not specifically part of this work order but formed part of the QC process lot
CAS Number = CAS registry number from database maintained by Chemical Abstracts Services. The Chemical Abstracts Service is a division of the American Chemical Society.
LOR = Limit of reporting
RPD = Relative Percentage Difference
= Indicates failed QC

Laboratory Duplicate (DUP) Report

The quality control term Laboratory Duplicate refers to a randomly selected intralaboratory split. Laboratory duplicates provide information regarding method precision and sample heterogeneity. The permitted ranges for the Relative Percent Deviation (RPD) of Laboratory Duplicates are specified in ALS Method QWI-EN/38 and are dependent on the magnitude of results in comparison to the level of reporting: Result < 10 times LOR: No Limit; Result between 10 and 20 times LOR: 0% - 50%; Result > 20 times LOR: 0% - 20%.

- **No Laboratory Duplicate (DUP) Results are required to be reported.**
-



Method Blank (MB) and Laboratory Control Sample (LCS) Report

The quality control term Method / Laboratory Blank refers to an analyte free matrix to which all reagents are added in the same volumes or proportions as used in standard sample preparation. The purpose of this QC parameter is to monitor potential laboratory contamination. The quality control term Laboratory Control Sample (LCS) refers to a certified reference material, or a known interference free matrix spiked with target analytes. The purpose of this QC parameter is to monitor method precision and accuracy independent of sample matrix. Dynamic Recovery Limits are based on statistical evaluation of processed LCS.

- **No Method Blank (MB) or Laboratory Control Spike (LCS) Results are required to be reported.**

Matrix Spike (MS) Report

The quality control term Matrix Spike (MS) refers to an intralaboratory split sample spiked with a representative set of target analytes. The purpose of this QC parameter is to monitor potential matrix effects on analyte recoveries. Static Recovery Limits as per laboratory Data Quality Objectives (DQOs). Ideal recovery ranges stated may be waived in the event of sample matrix interference.

- **No Matrix Spike (MS) or Matrix Spike Duplicate (MSD) Results are required to be reported.**
-



QA/QC Compliance Assessment to assist with Quality Review

Work Order	: EW2404887	Page	: 1 of 4
Client	: Ingenia Holidays Merry Beach	Laboratory	: Environmental Division NSW South Coast
Contact	: Gray Taylor	Telephone	: 02 42253125
Project	: Merry Beach Fresh /Drinking Water Monthly	Date Samples Received	: 24-Oct-2024
Site	: ----	Issue Date	: 29-Oct-2024
Sampler	: Tom Roose	No. of samples received	: 3
Order number	: P0501061	No. of samples analysed	: 3

This report is automatically generated by the ALS LIMS through interpretation of the ALS Quality Control Report and several Quality Assurance parameters measured by ALS. This automated reporting highlights any non-conformances, facilitates faster and more accurate data validation and is designed to assist internal expert and external Auditor review. Many components of this report contribute to the overall DQO assessment and reporting for guideline compliance.

Brief method summaries and references are also provided to assist in traceability.

Summary of Outliers

Outliers : Quality Control Samples

This report highlights outliers flagged in the Quality Control (QC) Report.

- **NO** Method Blank value outliers occur.
- **NO** Duplicate outliers occur.
- **NO** Laboratory Control outliers occur.
- **NO** Matrix Spike outliers occur.
- For all regular sample matrices, where applicable to the methodology, **NO** surrogate recovery outliers occur.

Outliers : Analysis Holding Time Compliance

- **NO** Analysis Holding Time Outliers exist.

Outliers : Frequency of Quality Control Samples

- **NO** Quality Control Sample Frequency Outliers exist.



Analysis Holding Time Compliance

If samples are identified below as having been analysed or extracted outside of recommended holding times, this should be taken into consideration when interpreting results.

This report summarizes extraction / preparation and analysis times and compares each with ALS recommended holding times (referencing USEPA SW 846, APHA, AS and NEPM) based on the sample container provided. Dates reported represent first date of extraction or analysis and preclude subsequent dilutions and reruns. A listing of breaches (if any) is provided herein.

Holding time for leachate methods (e.g. TCLP) vary according to the analytes reported. Assessment compares the leach date with the shortest analyte holding time for the equivalent soil method. These are: organics 14 days, mercury 28 days & other metals 180 days. A recorded breach does not guarantee a breach for all non-volatile parameters.

Holding times for VOC in soils vary according to analytes of interest. Vinyl Chloride and Styrene holding time is 7 days; others 14 days. A recorded breach does not guarantee a breach for all VOC analytes and should be verified in case the reported breach is a false positive or Vinyl Chloride and Styrene are not key analytes of interest/concern.

Matrix: **WATER** Evaluation: * = Holding time breach ; ✓ = Within holding time.

Method Container / Client Sample ID(s)	Sample Date	Extraction / Preparation			Analysis		
		Date extracted	Due for extraction	Evaluation	Date analysed	Due for analysis	Evaluation
MW006: Faecal Coliforms & E.coli by MF							
Sterile Plastic Bottle - Sodium Thiosulfate (MW006) Creek Tanks, Main tank, Pretty beach tank	24-Oct-2024	----	----	----	25-Oct-2024	25-Oct-2024	✓
MW007: Coliforms by MF							
Sterile Plastic Bottle - Sodium Thiosulfate (MW007) Creek Tanks, Main tank, Pretty beach tank	24-Oct-2024	----	----	----	25-Oct-2024	25-Oct-2024	✓



Quality Control Parameter Frequency Compliance

- No Quality Control data available for this section.
-



Brief Method Summaries

The analytical procedures used by the Environmental Division have been developed from established internationally recognized procedures such as those published by the US EPA, APHA, AS and NEPM. In house developed procedures are employed in the absence of documented standards or by client request. The following report provides brief descriptions of the analytical procedures employed for results reported in the Certificate of Analysis. Sources from which ALS methods have been developed are provided within the Method Descriptions.

<i>Analytical Methods</i>	<i>Method</i>	<i>Matrix</i>	<i>Method Descriptions</i>
Thermotolerant Coliforms & E.coli by Membrane Filtration	MW006	WATER	AS 4276.7
Coliforms by Membrane Filtration	MW007	WATER	AS 4276.5



SAMPLE RECEIPT NOTIFICATION (SRN)

Work Order : **EW2404704**

Client	: Ingenia Holidays Merry Beach	Laboratory	: Environmental Division NSW South Coast
Contact	: Gray Taylor	Contact	: Aneta Prosaroski
Address	: Merry Beach Road, Kioloa 2539	Address	: 1/19 Ralph Black Dr, North Wollongong 2500 NSW Australia
E-mail	: gtaylor@martens.com.au	E-mail	: Aneta.Prosaroski@ALSGlobal.com
Telephone	: 02 9476 9999	Telephone	: 02 42253125
Facsimile	: ----	Facsimile	: W 02 42253128 N 02 44232083
Project	: Merry Beach Monitoring - July 2024	Page	: 1 of 4
Order number	: P2108127	Quote number	: EW2024INGMER0001 (EW24INGMER0001)
C-O-C number	: ----	QC Level	: NEPM 2013 B3 & ALS QC Standard
Site	: ----		
Sampler	: Client - L B		

Dates

Date Samples Received	: 14-Oct-2024 12:30	Issue Date	: 14-Oct-2024
Client Requested Due Date	: 22-Oct-2024	Scheduled Reporting Date	: 22-Oct-2024

Delivery Details

Mode of Delivery	: Sampled By ALS	Security Seal	: Not Available
No. of coolers/boxes	: ----	Temperature	: 18.1, 19.9, 20.3
Receipt Detail	:	No. of samples received / analysed	: 3 / 3

General Comments

- This report contains the following information:
 - Sample Container(s)/Preservation Non-Compliances
 - Summary of Sample(s) and Requested Analysis
 - Proactive Holding Time Report
 - Requested Deliverables
- **Sample Disposal - Aqueous (3 weeks), Solid (2 months) from receipt of samples.**
- **Please direct any queries you have regarding this work order to the above ALS laboratory contact.**
- **Unless otherwise stated, analytical work for this work order will be conducted at ALS Sydney, NATA accreditation no. 825, site no. 10911.**
- Please be aware that APHA/NEPM recommends water and soil samples be chilled to less than or equal to 6°C for chemical analysis, and less than or equal to 10°C but unfrozen for Microbiological analysis. Where samples are received above this temperature, it should be taken into consideration when interpreting results. Refer to ALS EnviroMail 85 for ALS recommendations of the best practice for chilling samples after sampling and for maintaining a cool temperature during transit.
- **Please refer to the Proactive Holding Time Report table below which summarises breaches of recommended holding times that have occurred prior to samples/instructions being received at the laboratory. The laboratory will process these samples unless instructions are received from you indicating you do not wish to proceed. The absence of this summary table indicates that all samples have been received within the recommended holding times for the analysis requested.**



Sample Container(s)/Preservation Non-Compliances

All comparisons are made against pretreatment/preservation AS, APHA, USEPA standards.

- No sample container / preservation non-compliance exists.

Summary of Sample(s) and Requested Analysis

Some items described below may be part of a laboratory process necessary for the execution of client requested tasks. Packages may contain additional analyses, such as the determination of moisture content and preparation tasks, that are included in the package.

If no sampling time is provided, the sampling time will default 00:00 on the date of sampling. If no sampling date is provided, the sampling date will be assumed by the laboratory and displayed in brackets without a time component

Matrix: **WATER**

Laboratory sample ID	Sampling date / time	Sample ID	WATER - EK055G Ammonia as N By Discrete Analyser	WATER - EK059G Nitrite plus Nitrate as N (NOx) by Discrete	WATER - EN67 PK - Conductivity Field Tests - Conductivity- ALS Wollongong	WATER - EP030 BOD	WATER - MW006 (FC) Thermotolerant Coliforms by Membrane Filtration	WATER - MW023 Enterococci - Enumeration by Membrane	WATER - NT-09 TKN, Total Phosphorus
EW2404704-009	14-Oct-2024 00:00	884/SW1	✓	✓	✓	✓	✓	✓	✓
EW2404704-010	14-Oct-2024 00:00	884/SW2	✓	✓	✓	✓	✓	✓	✓
EW2404704-011	14-Oct-2024 00:00	884/SW3	✓	✓	✓	✓	✓	✓	✓

Matrix: **WATER**

Laboratory sample ID	Sampling date / time	Sample ID	WATER - EN67 PK - pH Field Tests - pH - ALS Wollongong	WATER - EN67 PK - Total Chlorine Field Tests - Total Chlorine - ALS Wollongong
EW2404704-009	14-Oct-2024 00:00	884/SW1	✓	✓
EW2404704-010	14-Oct-2024 00:00	884/SW2	✓	✓
EW2404704-011	14-Oct-2024 00:00	884/SW3	✓	✓

Proactive Holding Time Report

Sample(s) have been received within the recommended holding times for the requested analysis.



Requested Deliverables

ALL INVOICES FOR MERRY BEACH

- *AU Certificate of Analysis - NATA (COA)	Email	KBourke@ingeniacommunities.com.au
- *AU Interpretive QC Report - DEFAULT (Anon QCI Rep) (QCI)	Email	KBourke@ingeniacommunities.com.au
- *AU QC Report - DEFAULT (Anon QC Rep) - NATA (QC)	Email	KBourke@ingeniacommunities.com.au
- A4 - AU Sample Receipt Notification - Environmental HT (SRN)	Email	KBourke@ingeniacommunities.com.au
- A4 - AU Tax Invoice (INV)	Email	KBourke@ingeniacommunities.com.au
- Chain of Custody (CoC) (COC)	Email	KBourke@ingeniacommunities.com.au
- EDI Format - XTab (XTAB)	Email	KBourke@ingeniacommunities.com.au

Emily Jongsma

- *AU Certificate of Analysis - NATA (COA)	Email	ejongsma@martens.com.au
- *AU Interpretive QC Report - DEFAULT (Anon QCI Rep) (QCI)	Email	ejongsma@martens.com.au
- *AU QC Report - DEFAULT (Anon QC Rep) - NATA (QC)	Email	ejongsma@martens.com.au
- A4 - AU Sample Receipt Notification - Environmental HT (SRN)	Email	ejongsma@martens.com.au
- Chain of Custody (CoC) (COC)	Email	ejongsma@martens.com.au
- EDI Format - XTab (XTAB)	Email	ejongsma@martens.com.au

Gray Taylor

- *AU Certificate of Analysis - NATA (COA)	Email	gtaylor@martens.com.au
- *AU Interpretive QC Report - DEFAULT (Anon QCI Rep) (QCI)	Email	gtaylor@martens.com.au
- *AU QC Report - DEFAULT (Anon QC Rep) - NATA (QC)	Email	gtaylor@martens.com.au
- A4 - AU Sample Receipt Notification - Environmental HT (SRN)	Email	gtaylor@martens.com.au
- Chain of Custody (CoC) (COC)	Email	gtaylor@martens.com.au
- EDI Format - XTab (XTAB)	Email	gtaylor@martens.com.au

Harry Brazil

- *AU Certificate of Analysis - NATA (COA)	Email	hbrazil@ingeniaholidays.com.au
- *AU Interpretive QC Report - DEFAULT (Anon QCI Rep) (QCI)	Email	hbrazil@ingeniaholidays.com.au
- *AU QC Report - DEFAULT (Anon QC Rep) - NATA (QC)	Email	hbrazil@ingeniaholidays.com.au
- A4 - AU Sample Receipt Notification - Environmental HT (SRN)	Email	hbrazil@ingeniaholidays.com.au
- Chain of Custody (CoC) (COC)	Email	hbrazil@ingeniaholidays.com.au
- EDI Format - XTab (XTAB)	Email	hbrazil@ingeniaholidays.com.au

Mail Martens

- *AU Certificate of Analysis - NATA (COA)	Email	mail@martens.com.au
- *AU Interpretive QC Report - DEFAULT (Anon QCI Rep) (QCI)	Email	mail@martens.com.au
- *AU QC Report - DEFAULT (Anon QC Rep) - NATA (QC)	Email	mail@martens.com.au
- A4 - AU Sample Receipt Notification - Environmental HT (SRN)	Email	mail@martens.com.au
- Chain of Custody (CoC) (COC)	Email	mail@martens.com.au
- EDI Format - XTab (XTAB)	Email	mail@martens.com.au

Manager (Reports & Invoice)

- *AU Certificate of Analysis - NATA (COA)	Email	merrybeachmgr@ingeniaholidays.com.au
- *AU Interpretive QC Report - DEFAULT (Anon QCI Rep) (QCI)	Email	merrybeachmgr@ingeniaholidays.com.au
- *AU QC Report - DEFAULT (Anon QC Rep) - NATA (QC)	Email	merrybeachmgr@ingeniaholidays.com.au
- A4 - AU Sample Receipt Notification - Environmental HT (SRN)	Email	merrybeachmgr@ingeniaholidays.com.au
- A4 - AU Tax Invoice (INV)	Email	merrybeachmgr@ingeniaholidays.com.au
- Chain of Custody (CoC) (COC)	Email	merrybeachmgr@ingeniaholidays.com.au
- EDI Format - XTab (XTAB)	Email	merrybeachmgr@ingeniaholidays.com.au

Payables

- A4 - AU Tax Invoice (INV)	Email	payables@ingeniacommunities.com.au
-----------------------------	-------	------------------------------------



Trystan Richards

- | | | |
|--|-------|--------------------------|
| - *AU Certificate of Analysis - NATA (COA) | Email | trichards@martens.com.au |
| - *AU Interpretive QC Report - DEFAULT (Anon QCI Rep) (QCI) | Email | trichards@martens.com.au |
| - *AU QC Report - DEFAULT (Anon QC Rep) - NATA (QC) | Email | trichards@martens.com.au |
| - A4 - AU Sample Receipt Notification - Environmental HT (SRN) | Email | trichards@martens.com.au |
| - Chain of Custody (CoC) (COC) | Email | trichards@martens.com.au |
| - EDI Format - XTab (XTAB) | Email | trichards@martens.com.au |

Inter-Laboratory Testing

Analysis conducted by ALS Sydney, NATA accreditation no. 825, site no. 10911 (Chemistry / Biology).

(WATER) EK059G: Nitrite plus Nitrate as N (NOx) by Discrete Analyser

(WATER) EK055G: Ammonia as N by Discrete Analyser

(WATER) EK067G: Total Phosphorus as P by Discrete Analyser

(WATER) EK061G: Total Kjeldahl Nitrogen By Discrete Analyser

(WATER) EP030: Biochemical Oxygen Demand (BOD)

(WATER) MW023: Enterococci by Membrane Filtration

(WATER) MW006: Thermotolerant Coliforms & E.coli by MF

WATER ANALYSIS CHAIN OF CUSTODY

Project: Merry Beach Monitoring - June 2024	Laboratory: ALS (Australian Laboratory Services)	Delivery Details
Sampling Date:	Address: 4/13 Geary Place, North Nowra, NSW 2541	Dispatch Date:
Our reference: P2108127	Contact:	Shipment Method:
Results Required by:	Phone: (02) 4423 2063	
Our Contact: Gray Taylor	Facsimile: (02) 4423 2083	

Sample ID	Number of Containers	Analysis Required (X)												
		pH	Conductivity	Suspended Solids	BOD ₅	Phosphorous (total)	Nitrogen (total)	TKN	Ammonia	NOx	Faecal Col.	Enterococci	Oil and Grease	E. Coli
884/SW1	X	X	X	X	X	X	X	X	X	X	X	X	X	X
884/SW2	X	X	X	X	X	X	X	X	X	X	X	X	X	X
884/SW3	X	X	X	X	X	X	X	X	X	X	X	X	X	X
Influent	X	X	X	X	X	X	X	X	X	X	X	X	X	X

Notes: Fax (02 9476 8767) and email (gtaylor@martens.com.au; richards@martens.com.au; mail@martens.com.au; young.pete@gmail.com and merrybeachmgr@ingeniaholidays.com.au) results as soon as available, originals of laboratory reports to be posted to Merry Beach Caravan Park, KILOLA, NSW, 2539.

Lucas Butt
14/10/24

Wendy Mitchell
12³⁰
Jend
8.1, 19.9, 20.3



Environmental Engineering – Sustainable Solutions

Environmental

- EIS & REF
- Streams & rivers
- Coastal
- Groundwater
- Calcium
- Bushfire
- Monitoring

Geotechnics

- Foundations
- Geotechnical survey
- Contamination
- Excavations
- Hydrogeology
- Terrain analysis
- Waste management

Water

- Supply & storage
- Flooding
- Stormwater & drainage
- Wetlands
- Water quality
- Irrigation
- Water sensitive design

Wastewater

- Treatment
- Re-use
- Biosolids
- Design
- Management
- Monitoring
- Construction

Environmental Division
 Wollongong
 Work Order Reference
EW2404704

Head Office
 Suite 201,
 Hornsby N
 Ph 02 9474
 > mail@m
 www.mcr
 MARTENS &
 ABN 85 070 2





CERTIFICATE OF ANALYSIS

Work Order	: EW2404704	Page	: 1 of 3
Client	: Ingenia Holidays Merry Beach	Laboratory	: Environmental Division NSW South Coast
Contact	: Gray Taylor	Contact	: Aneta Prosaroski
Address	: Merry Beach Road, Kioloa 2539	Address	: 1/19 Ralph Black Dr, North Wollongong 2500 NSW Australia
Telephone	: 02 9476 9999	Telephone	: 02 42253125
Project	: Merry Beach Monitoring	Date Samples Received	: 14-Oct-2024 12:30
Order number	: P2108127	Date Analysis Commenced	: 14-Oct-2024
C-O-C number	: ----	Issue Date	: 22-Oct-2024 13:37
Sampler	: Client - L B		
Site	: ----		
Quote number	: EW24INGMER0001		
No. of samples received	: 3		
No. of samples analysed	: 3		



This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is carried out in compliance with procedures specified in 21 CFR Part 11.

Signatories	Position	Accreditation Category
Aneta Prosaroski	Environmental Services Representative	Laboratory - Wollongong, NSW
Dian Dao	Senior Chemist - Inorganics	Sydney Inorganics, Smithfield, NSW
Prasanna Ganta	Team Leader - Microbiology/Phycology	Sydney Microbiology, Smithfield, NSW



General Comments

The analytical procedures used by ALS have been developed from established internationally recognised procedures such as those published by the USEPA, APHA, AS and NEPM. In house developed procedures are fully validated and are often at the client request.

Where moisture determination has been performed, results are reported on a dry weight basis.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contract for details.

Key : CAS Number = CAS registry number from database maintained by Chemical Abstracts Services. The Chemical Abstracts Service is a division of the American Chemical Society.
LOR = Limit of reporting
^ = This result is computed from individual analyte detections at or above the level of reporting
ø = ALS is not NATA accredited for these tests.
~ = Indicates an estimated value.

- MF = membrane filtration
- CFU = colony forming unit
- Microbiological Comment: In accordance with ALS work instruction QWI-MIC/04, membrane filtration result is reported an approximate (~) when the count of colonies on the filtered membrane is outside the range of 10 - 100cfu.
- MW006 is ALS's internal code and is equivalent to AS4276.5.
- pH performed by ALS Wollongong via in-house method EA005FD and EN67 PK.
- Electrical conductivity performed by ALS Wollongong via in-house method EA010FD and EN67 PK.
- Chlorine analysis performed by ALS Wollongong via in-house method Ek010FD and EN67 PK.
- Samples provided by client and tested as received. Any analysis performed by ALS Wollongong were completed on date of receipt.
- MW023 is ALS's internal code and is equivalent to AS4276.9.



Analytical Results

Sub-Matrix: WATER (Matrix: WATER)			Sample ID	884/SW1	884/SW2	884/SW3	----	----
Sampling date / time			14-Oct-2024 00:00	14-Oct-2024 00:00	14-Oct-2024 00:00	----	----	
Compound	CAS Number	LOR	Unit	EW2404704-009	EW2404704-010	EW2404704-011	-----	-----
				Result	Result	Result	----	----
EA005FD: Field pH								
pH	----	0.1	pH Unit	6.8	6.9	7.1	----	----
EA010FD: Field Conductivity								
Conductivity @ 25oC	----	1	µS/cm	1410	3300	5560	----	----
EK010FD: Residual Chlorine								
Free Chlorine	----	0.02	mg/L	<0.02	0.04	0.03	----	----
EK055G: Ammonia as N by Discrete Analyser								
Ammonia as N	7664-41-7	0.01	mg/L	0.03	0.12	0.07	----	----
EK059G: Nitrite plus Nitrate as N (NOx) by Discrete Analyser								
Nitrite + Nitrate as N	----	0.01	mg/L	<0.01	0.01	<0.01	----	----
EK061G: Total Kjeldahl Nitrogen By Discrete Analyser								
Total Kjeldahl Nitrogen as N	----	0.1	mg/L	2.9	1.6	1.2	----	----
EK067G: Total Phosphorus as P by Discrete Analyser								
Total Phosphorus as P	----	0.01	mg/L	0.13	0.05	0.18	----	----
EP030: Biochemical Oxygen Demand (BOD)								
Biochemical Oxygen Demand	----	2	mg/L	6	4	4	----	----
MW006: Thermotolerant Coliforms & E.coli by MF								
Thermotolerant Coliforms	----	1	CFU/100mL	250	~1300	1200	----	----
MW023: Enterococci by Membrane Filtration								
Enterococci	----	1	CFU/100mL	65	2200	160	----	----

Inter-Laboratory Testing

Analysis conducted by ALS Sydney, NATA accreditation no. 825, site no. 10911 (Chemistry / Biology).

(WATER) EP030: Biochemical Oxygen Demand (BOD)

(WATER) MW023: Enterococci by Membrane Filtration

(WATER) EK059G: Nitrite plus Nitrate as N (NOx) by Discrete Analyser

(WATER) EK055G: Ammonia as N by Discrete Analyser

(WATER) MW006: Thermotolerant Coliforms & E.coli by MF

(WATER) EK067G: Total Phosphorus as P by Discrete Analyser

(WATER) EK061G: Total Kjeldahl Nitrogen By Discrete Analyser



QUALITY CONTROL REPORT

Work Order	: EW2404704	Page	: 1 of 3
Client	: Ingenia Holidays Merry Beach	Laboratory	: Environmental Division NSW South Coast
Contact	: Gray Taylor	Contact	: Aneta Prosaroski
Address	: Merry Beach Road, Kioloa 2539	Address	: 1/19 Ralph Black Dr, North Wollongong 2500 NSW Australia
Telephone	: 02 9476 9999	Telephone	: 02 42253125
Project	: Merry Beach Monitoring	Date Samples Received	: 14-Oct-2024
Order number	: P2108127	Date Analysis Commenced	: 14-Oct-2024
C-O-C number	: ----	Issue Date	: 22-Oct-2024
Sampler	: Client - L B		
Site	: ----		
Quote number	: EW24INGMER0001		
No. of samples received	: 3		
No. of samples analysed	: 3		



This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. This document shall not be reproduced, except in full.

This Quality Control Report contains the following information:

- Laboratory Duplicate (DUP) Report; Relative Percentage Difference (RPD) and Acceptance Limits
- Method Blank (MB) and Laboratory Control Spike (LCS) Report; Recovery and Acceptance Limits
- Matrix Spike (MS) Report; Recovery and Acceptance Limits

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is carried out in compliance with procedures specified in 21 CFR Part 11.

<i>Signatories</i>	<i>Position</i>	<i>Accreditation Category</i>
Aneta Prosaroski	Environmental Services Representative	Laboratory - Wollongong, NSW
Dian Dao	Senior Chemist - Inorganics	Sydney Inorganics, Smithfield, NSW
Prasanna Ganta	Team Leader - Microbiology/Phycology	Sydney Microbiology, Smithfield, NSW



General Comments

The analytical procedures used by ALS have been developed from established internationally recognised procedures such as those published by the USEPA, APHA, AS and NEPM. In house developed procedures are fully validated and are often at the client request.

Where moisture determination has been performed, results are reported on a dry weight basis.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis. Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Key :
 Anonymous = Refers to samples which are not specifically part of this work order but formed part of the QC process lot
 CAS Number = CAS registry number from database maintained by Chemical Abstracts Services. The Chemical Abstracts Service is a division of the American Chemical Society.
 LOR = Limit of reporting
 RPD = Relative Percentage Difference
 # = Indicates failed QC
 * = The final LOR has been raised due to dilution or other sample specific cause; adjusted LOR is shown in brackets. The duplicate ranges for Acceptable RPD% are applied to the final LOR where applicable.

Laboratory Duplicate (DUP) Report

The quality control term Laboratory Duplicate refers to a randomly selected intralaboratory split. Laboratory duplicates provide information regarding method precision and sample heterogeneity. The permitted ranges for the Relative Percent Deviation (RPD) of Laboratory Duplicates are specified in ALS Method QWI-EN/38 and are dependent on the magnitude of results in comparison to the level of reporting: Result < 10 times LOR: No Limit; Result between 10 and 20 times LOR: 0% - 50%; Result > 20 times LOR: 0% - 20%.

Sub-Matrix: **WATER**

				Laboratory Duplicate (DUP) Report					
Laboratory sample ID	Sample ID	Method: Compound	CAS Number	LOR	Unit	Original Result	Duplicate Result	RPD (%)	Acceptable RPD (%)
EK055G: Ammonia as N by Discrete Analyser (QC Lot: 6130010)									
ES2433899-007	Anonymous	EK055G: Ammonia as N	7664-41-7	0.01	mg/L	0.08	0.09	0.0	No Limit
EW2404737-004	Anonymous	EK055G: Ammonia as N	7664-41-7	0.01	mg/L	0.01	0.02	58.7	No Limit
EK059G: Nitrite plus Nitrate as N (NOx) by Discrete Analyser (QC Lot: 6130009)									
ES2433862-001	Anonymous	EK059G: Nitrite + Nitrate as N	----	0.01	mg/L	<0.01	<0.01	0.0	No Limit
EW2404737-004	Anonymous	EK059G: Nitrite + Nitrate as N	----	0.01	mg/L	0.27	0.27	0.0	0% - 20%
EK061G: Total Kjeldahl Nitrogen By Discrete Analyser (QC Lot: 6130004)									
ES2433785-001	Anonymous	EK061G: Total Kjeldahl Nitrogen as N	----	0.1 (2.0)*	mg/L	27.6	26.9	2.9	0% - 50%
EW2404731-002	Anonymous	EK061G: Total Kjeldahl Nitrogen as N	----	0.1	mg/L	0.8	0.7	0.0	No Limit
EK067G: Total Phosphorus as P by Discrete Analyser (QC Lot: 6130005)									
ES2433785-001	Anonymous	EK067G: Total Phosphorus as P	----	0.01 (0.20)*	mg/L	6.50	6.10	6.5	0% - 20%
EW2404731-002	Anonymous	EK067G: Total Phosphorus as P	----	0.01	mg/L	0.13	0.14	11.7	0% - 50%
EP030: Biochemical Oxygen Demand (BOD) (QC Lot: 6121319)									
ES2433457-005	Anonymous	EP030: Biochemical Oxygen Demand	----	2	mg/L	12	18	44.0	No Limit
ES2433603-001	Anonymous	EP030: Biochemical Oxygen Demand	----	2	mg/L	32	31	5.3	0% - 50%



Method Blank (MB) and Laboratory Control Sample (LCS) Report

The quality control term Method / Laboratory Blank refers to an analyte free matrix to which all reagents are added in the same volumes or proportions as used in standard sample preparation. The purpose of this QC parameter is to monitor potential laboratory contamination. The quality control term Laboratory Control Sample (LCS) refers to a certified reference material, or a known interference free matrix spiked with target analytes. The purpose of this QC parameter is to monitor method precision and accuracy independent of sample matrix. Dynamic Recovery Limits are based on statistical evaluation of processed LCS.

Sub-Matrix: **WATER**

Method: Compound	CAS Number	LOR	Unit	Method Blank (MB) Report	Laboratory Control Spike (LCS) Report			
				Result	Spike Concentration	Spike Recovery (%) LCS	Acceptable Limits (%) Low High	
EK055G: Ammonia as N by Discrete Analyser (QCLot: 6130010)								
EK055G: Ammonia as N	7664-41-7	0.01	mg/L	<0.01	0.5 mg/L	104	90.0	114
EK059G: Nitrite plus Nitrate as N (NOx) by Discrete Analyser (QCLot: 6130009)								
EK059G: Nitrite + Nitrate as N	----	0.01	mg/L	<0.01	0.5 mg/L	101	91.0	113
EK061G: Total Kjeldahl Nitrogen By Discrete Analyser (QCLot: 6130004)								
EK061G: Total Kjeldahl Nitrogen as N	----	0.1	mg/L	<0.1	10 mg/L	94.6	69.0	123
				<0.1	1 mg/L	115	70.0	123
				<0.1	5 mg/L	96.6	70.0	123
EK067G: Total Phosphorus as P by Discrete Analyser (QCLot: 6130005)								
EK067G: Total Phosphorus as P	----	0.01	mg/L	<0.01	4.42 mg/L	99.4	71.3	126
				<0.01	0.442 mg/L	119	71.3	126
				<0.01	1 mg/L	100	70.0	130
EP030: Biochemical Oxygen Demand (BOD) (QCLot: 6121319)								
EP030: Biochemical Oxygen Demand	----	2	mg/L	<2	200 mg/L	92.5	74.0	112

Matrix Spike (MS) Report

The quality control term Matrix Spike (MS) refers to an intralaboratory split sample spiked with a representative set of target analytes. The purpose of this QC parameter is to monitor potential matrix effects on analyte recoveries. Static Recovery Limits as per laboratory Data Quality Objectives (DQOs). Ideal recovery ranges stated may be waived in the event of sample matrix interference.

Sub-Matrix: **WATER**

Laboratory sample ID	Sample ID	Method: Compound	CAS Number	Matrix Spike (MS) Report		
				Spike Concentration	Spike Recovery (%) MS	Acceptable Limits (%) Low High
EK055G: Ammonia as N by Discrete Analyser (QCLot: 6130010)						
ES2433899-007	Anonymous	EK055G: Ammonia as N	7664-41-7	0.5 mg/L	90.5	70.0 130
EK059G: Nitrite plus Nitrate as N (NOx) by Discrete Analyser (QCLot: 6130009)						
ES2433862-001	Anonymous	EK059G: Nitrite + Nitrate as N	----	0.5 mg/L	93.8	70.0 130
EK061G: Total Kjeldahl Nitrogen By Discrete Analyser (QCLot: 6130004)						
ES2433862-001	Anonymous	EK061G: Total Kjeldahl Nitrogen as N	----	5 mg/L	89.8	70.0 130
EK067G: Total Phosphorus as P by Discrete Analyser (QCLot: 6130005)						
ES2433862-001	Anonymous	EK067G: Total Phosphorus as P	----	1 mg/L	91.9	70.0 130



QA/QC Compliance Assessment to assist with Quality Review

Work Order	: EW2404704	Page	: 1 of 5
Client	: Ingenia Holidays Merry Beach	Laboratory	: Environmental Division NSW South Coast
Contact	: Gray Taylor	Telephone	: 02 42253125
Project	: Merry Beach Monitoring	Date Samples Received	: 14-Oct-2024
Site	: ----	Issue Date	: 22-Oct-2024
Sampler	: Client - L B	No. of samples received	: 3
Order number	: P2108127	No. of samples analysed	: 3

This report is automatically generated by the ALS LIMS through interpretation of the ALS Quality Control Report and several Quality Assurance parameters measured by ALS. This automated reporting highlights any non-conformances, facilitates faster and more accurate data validation and is designed to assist internal expert and external Auditor review. Many components of this report contribute to the overall DQO assessment and reporting for guideline compliance.

Brief method summaries and references are also provided to assist in traceability.

Summary of Outliers

Outliers : Quality Control Samples

This report highlights outliers flagged in the Quality Control (QC) Report.

- **NO Method Blank value outliers occur.**
- **NO Duplicate outliers occur.**
- **NO Laboratory Control outliers occur.**
- **NO Matrix Spike outliers occur.**
- For all regular sample matrices, where applicable to the methodology, **NO surrogate recovery outliers occur.**

Outliers : Analysis Holding Time Compliance

- **NO Analysis Holding Time Outliers exist.**

Outliers : Frequency of Quality Control Samples

- **NO Quality Control Sample Frequency Outliers exist.**



Analysis Holding Time Compliance

If samples are identified below as having been analysed or extracted outside of recommended holding times, this should be taken into consideration when interpreting results.

This report summarizes extraction / preparation and analysis times and compares each with ALS recommended holding times (referencing USEPA SW 846, APHA, AS and NEPM) based on the sample container provided. Dates reported represent first date of extraction or analysis and preclude subsequent dilutions and reruns. A listing of breaches (if any) is provided herein.

Holding time for leachate methods (e.g. TCLP) vary according to the analytes reported. Assessment compares the leach date with the shortest analyte holding time for the equivalent soil method. These are: organics 14 days, mercury 28 days & other metals 180 days. A recorded breach does not guarantee a breach for all non-volatile parameters.

Holding times for VOC in soils vary according to analytes of interest. Vinyl Chloride and Styrene holding time is 7 days; others 14 days. A recorded breach does not guarantee a breach for all VOC analytes and should be verified in case the reported breach is a false positive or Vinyl Chloride and Styrene are not key analytes of interest/concern.

Matrix: **WATER** Evaluation: * = Holding time breach ; ✓ = Within holding time.

Method Container / Client Sample ID(s)	Sample Date	Extraction / Preparation			Analysis			
		Date extracted	Due for extraction	Evaluation	Date analysed	Due for analysis	Evaluation	
EA005FD: Field pH								
Field Test Dummy Bottle (EN67 PK) 884/SW1, 884/SW3	884/SW2,	14-Oct-2024	----	----	----	14-Oct-2024	----	----
EA010FD: Field Conductivity								
Field Test Dummy Bottle (EN67 PK) 884/SW1, 884/SW3	884/SW2,	14-Oct-2024	----	----	----	14-Oct-2024	----	----
EK010FD: Residual Chlorine								
Field Test Dummy Bottle (EN67 PK) 884/SW1, 884/SW3	884/SW2,	14-Oct-2024	----	----	----	14-Oct-2024	----	----
EK055G: Ammonia as N by Discrete Analyser								
Clear Plastic Bottle - Sulfuric Acid (EK055G) 884/SW1, 884/SW3	884/SW2,	14-Oct-2024	----	----	----	18-Oct-2024	11-Nov-2024	✓
EK059G: Nitrite plus Nitrate as N (NOx) by Discrete Analyser								
Clear Plastic Bottle - Sulfuric Acid (EK059G) 884/SW1, 884/SW3	884/SW2,	14-Oct-2024	----	----	----	18-Oct-2024	11-Nov-2024	✓
EK061G: Total Kjeldahl Nitrogen By Discrete Analyser								
Clear Plastic Bottle - Sulfuric Acid (EK061G) 884/SW1, 884/SW3	884/SW2,	14-Oct-2024	18-Oct-2024	11-Nov-2024	✓	21-Oct-2024	11-Nov-2024	✓
EK067G: Total Phosphorus as P by Discrete Analyser								
Clear Plastic Bottle - Sulfuric Acid (EK067G) 884/SW1, 884/SW3	884/SW2,	14-Oct-2024	18-Oct-2024	11-Nov-2024	✓	21-Oct-2024	11-Nov-2024	✓
EP030: Biochemical Oxygen Demand (BOD)								
Clear Plastic Bottle - Natural (EP030) 884/SW1, 884/SW3	884/SW2,	14-Oct-2024	----	----	----	15-Oct-2024	16-Oct-2024	✓



Matrix: **WATER** Evaluation: ✖ = Holding time breach ; ✔ = Within holding time.

Method Container / Client Sample ID(s)	Sample Date	Extraction / Preparation			Analysis			
		Date extracted	Due for extraction	Evaluation	Date analysed	Due for analysis	Evaluation	
MW006: Thermotolerant Coliforms & E.coli by MF								
Sterile Plastic Bottle - Sodium Thiosulfate (MW006) 884/SW1, 884/SW3	884/SW2,	14-Oct-2024	----	----	----	15-Oct-2024	15-Oct-2024	✔
MW023: Enterococci by Membrane Filtration								
Sterile Plastic Bottle - Sodium Thiosulfate (MW023) 884/SW1, 884/SW3	884/SW2,	14-Oct-2024	----	----	----	15-Oct-2024	15-Oct-2024	✔



Quality Control Parameter Frequency Compliance

The following report summarises the frequency of laboratory QC samples analysed within the analytical lot(s) in which the submitted sample(s) was(were) processed. Actual rate should be greater than or equal to the expected rate. A listing of breaches is provided in the Summary of Outliers.

Matrix: **WATER** Evaluation: * = Quality Control frequency not within specification ; ✓ = Quality Control frequency within specification.

Quality Control Sample Type	Method	Count		Rate (%)			Quality Control Specification
		QC	Regular	Actual	Expected	Evaluation	
Analytical Methods							
Laboratory Duplicates (DUP)							
Ammonia as N by Discrete analyser	EK055G	2	13	15.38	10.00	✓	NEPM 2013 B3 & ALS QC Standard
Biochemical Oxygen Demand (BOD)	EP030	2	15	13.33	10.00	✓	NEPM 2013 B3 & ALS QC Standard
Nitrite and Nitrate as N (NOx) by Discrete Analyser	EK059G	2	17	11.76	10.00	✓	NEPM 2013 B3 & ALS QC Standard
Total Kjeldahl Nitrogen as N By Discrete Analyser	EK061G	2	17	11.76	10.00	✓	NEPM 2013 B3 & ALS QC Standard
Total Phosphorus as P By Discrete Analyser	EK067G	2	18	11.11	10.00	✓	NEPM 2013 B3 & ALS QC Standard
Laboratory Control Samples (LCS)							
Ammonia as N by Discrete analyser	EK055G	1	13	7.69	5.00	✓	NEPM 2013 B3 & ALS QC Standard
Biochemical Oxygen Demand (BOD)	EP030	1	15	6.67	5.00	✓	NEPM 2013 B3 & ALS QC Standard
Nitrite and Nitrate as N (NOx) by Discrete Analyser	EK059G	1	17	5.88	5.00	✓	NEPM 2013 B3 & ALS QC Standard
Total Kjeldahl Nitrogen as N By Discrete Analyser	EK061G	3	17	17.65	15.00	✓	NEPM 2013 B3 & ALS QC Standard
Total Phosphorus as P By Discrete Analyser	EK067G	3	18	16.67	15.00	✓	NEPM 2013 B3 & ALS QC Standard
Method Blanks (MB)							
Ammonia as N by Discrete analyser	EK055G	1	13	7.69	5.00	✓	NEPM 2013 B3 & ALS QC Standard
Biochemical Oxygen Demand (BOD)	EP030	1	15	6.67	5.00	✓	NEPM 2013 B3 & ALS QC Standard
Nitrite and Nitrate as N (NOx) by Discrete Analyser	EK059G	1	17	5.88	5.00	✓	NEPM 2013 B3 & ALS QC Standard
Total Kjeldahl Nitrogen as N By Discrete Analyser	EK061G	1	17	5.88	5.00	✓	NEPM 2013 B3 & ALS QC Standard
Total Phosphorus as P By Discrete Analyser	EK067G	1	18	5.56	5.00	✓	NEPM 2013 B3 & ALS QC Standard
Matrix Spikes (MS)							
Ammonia as N by Discrete analyser	EK055G	1	13	7.69	5.00	✓	NEPM 2013 B3 & ALS QC Standard
Nitrite and Nitrate as N (NOx) by Discrete Analyser	EK059G	1	17	5.88	5.00	✓	NEPM 2013 B3 & ALS QC Standard
Total Kjeldahl Nitrogen as N By Discrete Analyser	EK061G	1	17	5.88	5.00	✓	NEPM 2013 B3 & ALS QC Standard
Total Phosphorus as P By Discrete Analyser	EK067G	1	18	5.56	5.00	✓	NEPM 2013 B3 & ALS QC Standard



Brief Method Summaries

The analytical procedures used by the Environmental Division have been developed from established internationally recognized procedures such as those published by the US EPA, APHA, AS and NEPM. In house developed procedures are employed in the absence of documented standards or by client request. The following report provides brief descriptions of the analytical procedures employed for results reported in the Certificate of Analysis. Sources from which ALS methods have been developed are provided within the Method Descriptions.

Analytical Methods	Method	Matrix	Method Descriptions
Ammonia as N by Discrete analyser	EK055G	WATER	In house: Referenced to APHA 4500-NH ₃ G Ammonia is determined by direct colorimetry by Discrete Analyser. This method is compliant with NEPM Schedule B(3)
Nitrite and Nitrate as N (NO _x) by Discrete Analyser	EK059G	WATER	In house: Referenced to APHA 4500-NO ₃ - F. Combined oxidised Nitrogen (NO ₂ +NO ₃) is determined by Chemical Reduction and direct colourimetry by Discrete Analyser. This method is compliant with NEPM Schedule B(3)
Total Kjeldahl Nitrogen as N By Discrete Analyser	EK061G	WATER	In house: Referenced to APHA 4500-Norg D (In house). An aliquot of sample is digested using a high temperature Kjeldahl digestion to convert nitrogenous compounds to ammonia. Ammonia is determined colorimetrically by discrete analyser. This method is compliant with NEPM Schedule B(3)
Total Phosphorus as P By Discrete Analyser	EK067G	WATER	In house: Referenced to APHA 4500-P H, Jirka et al, Zhang et al. This procedure involves sulphuric acid digestion of a sample aliquot to break phosphorus down to orthophosphate. The orthophosphate reacts with ammonium molybdate and antimony potassium tartrate to form a complex which is then reduced and its concentration measured at 880nm using discrete analyser. This method is compliant with NEPM Schedule B(3)
Field Tests - Port Kembla	EN67 PK	WATER	Field determinations as per methods described in APHA. The analysis is performed in the field by ALS samplers. ALS NATA accreditation apply for this service.
Biochemical Oxygen Demand (BOD)	EP030	WATER	In house: Referenced to APHA 5210 B. The 5-Day BOD test provides an empirical measure of the oxygen consumption capacity of a given water. A portion of the sample is diluted into oxygenated, nutrient rich water, and a seed added to begin biological decay. The initial dissolved oxygen content is measured, then the bottle is sealed and incubated for five days. The remaining dissolved oxygen is measured, and from the difference, the demand for oxygen, by biological decay, is determined. This method is compliant with NEPM Schedule B(3).
Thermotolerant Coliforms & E.coli by Membrane Filtration	MW006	WATER	AS 4276.7
Enumeration of Enterococci by Membrane Filtration	MW023	WATER	AS4276.9
Preparation Methods	Method	Matrix	Method Descriptions
TKN/TP Digestion	EK061/EK067	WATER	In house: Referenced to APHA 4500 Norg - D; APHA 4500 P - H. This method is compliant with NEPM Schedule B(3)